



Attention: **Transportation Planning**
 City of Hamilton
 71 Main Street West
 Hamilton, Ontario L8P 4Y5

Date: February 24, 2023

Regarding: **HAM-21006281-00 559 Garner Road East, Ancaster**

To whom it may concern,

This letter is to confirm that the suspended cast in place reinforced concrete slab supporting the road base along the fire access route will be designed for surcharge loads due to traffic in accordance with the Ontario Building Code for fire/garbage truck loads (total 352 kN (35,880 kg)) but not less than 12 kPa.

Kindest Regards,

A handwritten signature in black ink that reads 'Gordon Ho' in a cursive style.

Gordon Ho, P.Eng., M.A.Sc.
Vice President, Structural
t: +1.905.695.3217, 63726
m: +1.416.873.0284
e: Gordon.Ho@exp.com