



Project No: 221-10826-00

August 29, 2023

Anthony Girolami
Fengate Asset Management
2275 Upper Middle Road East, Unit 700
Oakville, ON L6H 0C3

Subject: 3054 Homestead Drive Development – Watermain Hydraulic Analysis

Dear Mr. Girolami,

WSP Canada Inc. (WSP) is pleased to present the updated results of the watermain hydraulic analysis for the proposed 3054 Homestead Drive development in the City of Hamilton. This analysis addresses the City's comments dated May 17, 2023, and reflects the most up-to-date water servicing plan for the development.

The analysis in this report includes hydraulic simulation of the Average Day, Maximum Day, Maximum Day plus Fire Flow and the Peak Hour demand scenarios at the proposed development for 2021 (present) and 2031 (future) planning horizons. The hydraulic analysis was completed using a WaterGEMS model of the Hamilton water distribution network for Pressure District (PD) 6, and the existing PD6 demands were updated in June 2023 to reflect the ongoing Master Plan.

The modelling shows that the development can achieve the pressure requirements prescribed by the City of Hamilton, the Ministry of the Environment, Conservation and Parks (MECP) watermain design criteria and the Ontario Building Code (OBC) Compendium under all conditions. WSP conducted baseline analyses without the proposed development to examine the impact on the existing network capacity to deliver fire flow. If any changes or discrepancies are contemplated with the final design plan, the analysis in this report should be updated with the required fire flows.

If you have any questions, please do not hesitate to call.

Yours truly,

WSP Canada Inc.



Antoine Lahaie, P.Eng., PMP
Project Manager, Hydraulics

Charlotte Xie, E.I.T.,
B.A.Sc., Hydraulics

TABLE OF CONTENTS

1	INTRODUCTION	1
2	DESIGN CRITERIA	2
2.1	Domestic Water Demands	2
2.2	Pressures	3
2.3	Required Fire Flow	3
3	HYDRAULIC MODEL	4
3.1	Boundary Conditions	4
3.2	3054 Homestead Drive Development	5
3.3	Verification of Model Calibration	5
4	HYDRAULIC ANALYSIS	6
4.1	System Pressures	6
4.2	Available Fire flow	7
4.2.1	Manual Fire Flow	9
4.3	Transient Pressures	10
4.4	System Flushing	10
5	CONCLUSIONS	11

TABLES

TABLE 2-1: DEMAND FACTORS AND INPUTS.....	2
TABLE 2-2: SUMMARY OF TARGET AVAILABLE FIRE FLOW	3
TABLE 3-1: PD6 AND PD25 DEMAND UPDATE IN WSP'S MODEL.....	4
TABLE 3-2: PUMP STATUS AT HD06A AND HD06B PS UNDER THE SIMULATED 2021 AND 2031 PLANNING HORIZONS	5
TABLE 3-3: HAZEN-WILLIAMS C-FACTORS	5
TABLE 4-1: SIMULATED PRESSURES FOR PHASE 1 WITH 50% TWL.....	6
TABLE 4-2: SIMULATED PRESSURES FOR PHASE 1 WITH 70% TWL	6
TABLE 4-3: SIMULATED PRESSURES FOR ULTIMATE BUILDOUT WITH 50% TWL.....	6
TABLE 4-4: SIMULATED PRESSURES FOR ULTIMATE BUILDOUT WITH 70% TWL	7
TABLE 4-5: SIMULATED PRESSURES FOR ULTIMATE BUILDOUT (OPTION 2) WITH 50% TWL.....	7
TABLE 4-6: SIMULATED PRESSURES FOR ULTIMATE BUILDOUT (OPTION 2) WITH 70% TWL.....	7
TABLE 4-7: SIMULATED AVAILABLE FIRE FLOWS AT HYDRANTS UNDER PHASE 1.....	7
TABLE 4-8: SIMULATED AVAILABLE FIRE FLOWS AT HYDRANTS UNDER ULTIMATE BUILDOUT	8
TABLE 4-9: SIMULATED AVAILABLE FIRE FLOWS AT HYDRANTS UNDER ULTIMATE BUILDOUT (OPTION 2).....	8
TABLE 4-10: SIMULATED AVAILABLE FIRE FLOWS ON EXISTING HYDRANTS WITH 70% TWL.....	9
TABLE 4-11: MANUAL FIRE FLOW RESULT SUMMARY	9

FIGURES

FIGURE 1- 1: THE PROPOSED 3054 HOMESTEAD DRIVE DEVELOPMENT SITE PLAN	1
FIGURE 1- 2: THE PROPOSED 3054 HOMESTEAD DRIVE DEVELOPMENT SITE PLAN (OPTION 2).....	2



APPENDICES

- A** DEMANDS AND PROPOSED SYSTEM LAYOUT
- B** PIPE AND JUNCTION TABLES
- C** FIRE FLOW REPORT
- D** FLUSHING REPORT
- E** HYDRANT FLOW TEST RESULTS

1 INTRODUCTION

The 3054 Homestead Drive development will be located at the northwest corner of Homestead Drive and Airport Road and at 9174&9166 Airport Road West in the City of Hamilton, Ontario. The purpose of this report is to complete the water servicing analysis for the proposed development, consisting of 4 industrial buildings.

The proposed development is located within Pressures District 6 (PD6) of the City of Hamilton water distribution network and will be built in two phases. Building D will be built as part of Phase 1 while Building A, B, and C will be built as part of Phase 2. The Phase 1 development will be serviced by a 300mm connection to the existing 400mm watermain along Airport Road to the south. The ultimate buildout of the development will be serviced by the proposed 300mm network with two connections to the existing 400mm watermains on Airport Road and Homestead Drive. Alternatively, the 300mm network will tie into the future Rice Group development to the north and eventually connect to the existing 400mm watermain on Homestead Dr (Option 2). Figure 1-1 and Figure 1-2 show the two concept site plans of the proposed development.

The proposed water servicing system layout, including the proposed pipe diameters, can be found in Appendix A of the report.




Figure 1- 1: The Proposed 3054 Homestead Drive Development Site Plan




Figure 1- 2: The Proposed 3054 Homestead Drive Development Site Plan (Option 2)

2 DESIGN CRITERIA

2.1 DOMESTIC WATER DEMANDS

The domestic demands for the 3054 Homestead Drive development were calculated using the City of Hamilton's Engineering Guidelines for Servicing Land under Development Applications, December 2012. Population density for industrial units were determined according to the City of Hamilton Development Charge Background Study by Watson & Associates Economists Ltd, October 2019. Accordingly, the density for Industrial properties of 125 persons/ha was applied for the calculation. Table 2-1 lists the factors used to determine the demands for the development.

Table 2-1: Demand Factors and Inputs

DEMAND FACTORS AND INPUTS	VALUE
Single Family Detached Homes	3.39 persons/unit
Townhomes	2.45 persons/unit
Industrial	125 persons/ha
Residential Average Day Demand	360 L/Person/day
ICI Average Day Demand	260 L/Perons/day
Maximum Day Peaking Factor	1.9
Peak Hour Factor	3.0

Detailed calculations of domestic demands are shown in Appendix A. Domestic demands for the development were calculated by multiplying the estimated footprint area for the each building and the population density for industrial sites, and allocated to the closest junctions along the proposed watermain in the water model. Demands external to the development, including the Dickenson and Shelby Developments, were unchanged.

2.2 PRESSURES

As outlined in the City of Hamilton Water and Wastewater Master Plan, 2006 (WWWMP), the acceptable pressures under normal conditions are between 275 kPa (40 psi) and 690 kPa (100 psi).

The minimum allowable pressure under Maximum Day Demand plus Fire Flow is 140 kPa at the location of the fire and/or everywhere else in the pressure district.

2.3 REQUIRED FIRE FLOW

Required Fire Flow calculations were not available at the time of this analysis. As part of the City of Hamilton's fire flow requirement, the RFF targets for this development should be the higher of the calculated fire flows using the OBC method or the fire flow targets from the City's policy as shown in Table 2-2.

Table 2-2: Summary of Target Available Fire Flow

LAND USE	TARGET AVAILABLE FIRE FLOW (L/S)
Commercial	150
Small I/I (<1800m ³) ¹	100
Industrial	250
Institutional	150
Residential Multi ²	150
Residential Medium (3 or less units) ³	125
Residential Single	75
Residential Single (Dead End)	50

1) 1800m³ represents a maximum building volume that qualifies as "Small ICI"

2) Residential Multi is defined as a residential dwelling with > 3 units

3) Residential Medium is defined as a residential dwelling with ≤ 3 units

As a conservative approach, the required fire flow (RFF) of 250 L/s for industrial sites was applied to all hydrants within the proposed 3054 Homestead Drive development.

3 HYDRAULIC MODEL

The proposed development will be located within Pressure District (PD) 6 of the City of Hamilton's water network. It will be supplied by the HD06A (Stone Church Road at Garth) and the HD06B (Stone Church Road at Tunbridge Crescent) pumping stations.

The development was added to an existing hydraulic model of the City of Hamilton received by WSP in March 2017 in the context of the Pressure District Characterization Study. Since the time of receipt, WSP has been updating the model with various developments (either approved or under review).

As part of the modeling completed in this study, WSP updated the total demands in the Pressure District (PD) 6 and 25 as to have them match the ongoing Master Plan Models provided by the City in June, 2023.

Table 3-1 summarizes the sum of demands for PD6 and PD25 in WSP's model after the update.

Table 3-1: PD6 and PD25 Demand Update in WSP's Model

	AVERAGE DAY (L/S)	MAXIMUM DAY (L/S)	PEAK HOUR DEMAND (L/S)
PD6+PD25 2021 Demand	561.26	868.76	1,244.47
PD6+PD25 2031 Demand	630.29	975.62	1,397.54

Note: the 2031 demands update in PD6 and PD25 were calculated from the 2021 demands assuming a growth rate of 12.3% approved by the City. Once the final growth data from the ongoing City of Hamilton Master Plan Study is determined, the 2031 demands will need be updated.

3.1 BOUNDARY CONDITIONS

PD6 is a closed zone that is supplied by two (2) booster pumping stations: HD06A (Stone Church Road at Garth) and HD06B (Stone Church Road at Tunbridge Crescent). The HD06A pumping station is supplied by the HDR05 reservoir while the HD06B pumping station receives water through a 1,200 mm PD5 trunk main.

The analysis was carried out with the hydraulic grade line (HGL) in the HDR05 reservoir, set to 232.32m and 233.88m for all 2021 and 2031 scenarios of both planning horizons. These water levels represent a tank at approximately 50% and 70% full, respectively.

Additionally, the Lavender Drive and Upper Paradise Road PRVs in PD6 were open (active) in the model during these conditions and had HGL settings of 238.80 m and 252.49 m, respectively.

The modelled discharge pressure at HD06A pumping station was limited to 480kPa via recirculation through a PSV. This is consistent with the City of Hamilton's Water Outstation Process Narrative for HD06A. The status of each pump during all modelled scenarios of this analysis is outlined in Table 3-2.

Table 3-2: Pump Status at HD06A and HD06B PS under the simulated 2021 and 2031 planning horizons

Pump Station	Pump	2021 AVG	2021 MDD	2021 PHD	2021 MDD+FF	2031 AVG	2031 MDD	2031 PHD	2031 MDD+FF
HDO6A ¹	HLP1	ON	ON	ON	ON	ON	ON	ON	ON
	HLP3	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
	HLP4	ON	ON	ON	ON	ON	ON	ON	ON
	HLP5	OFF	ON	ON	ON	OFF	ON	ON	ON
HDO6B	HLP1	ON	ON	ON	ON	ON	ON	ON	ON
	HLP2	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
	HLP4	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF

Note:

1. The discharge pressure at the pump station, HD06A, was kept just under 480kPa for all the scenarios based on the Water Outstation Process Control Narrative (section 5.4.2.2 in appendix at page 13 of 29).

3.2 3054 HOMESTEAD DRIVE DEVELOPMENT

The proposed watermains and water services were added to the PD6 pressure district and reflect the proposed servicing plan provided by the Client on December 16th, 2022. The servicing plan was added to Appendix A for ease of reference.

Elevation information within the development was taken as the finished grade elevation at the centerline of the road or applicable adjacent proposed grade point. Service elevations range from 229 m to 235.4 m within the proposed development.

The friction (C) factors for all new pipes added to the model were assigned according to the Ministry of the Environment, Conservation and Parks (MECP) watermain Design criteria as listed in Table 3-1. Internal diameters of the pipes were modelled to improve the accuracy of results.

Table 3-3: Hazen-Williams C-Factors

DIAMETER (NOMINAL)	C-FACTOR
150 mm (ID 152.5 mm)	100
200 mm (ID 204 mm)	110
300 mm (ID 290 mm)	120

The proposed layout of the water distribution system is intended to satisfy the requirements of the City of Hamilton. All pipes and nodes added for the development are shown and identified in Appendix A.

3.3 VERIFICATION OF MODEL CALIBRATION

The hydraulic model calibration was verified using the results of hydrant flow tests conducted by WSP. These tests were completed by the City on October 22nd, 2022 at the following locations:

1. Hydrant GJ10H011 on 9079 Airport Road West, Mount Hope, ON.
2. Hydrant GJ10H006 on 3026 Homestead Drive, Mount Hope, ON.

Results of these hydrant flow tests are included in Appendix E. A comparison between the results of the hydrant flow tests and the modeled hydrant flow curves was done at the locations of the proposed development site. It was found that the modeled static pressures were within 5% of the hydrant flow test static pressures and that the modeled flows at 140 kPa (20 psi) were conservative in that the flow estimated by the model is lower than that calculated from the hydrant test. Appendix E provides detailed results of the hydrant test and model validation.

4 HYDRAULIC ANALYSIS

The suggested watermain layout was modelled for Average Day, Maximum Day, Maximum Day plus Fire Flow and Peak Hour scenarios under the present (2021) and ultimate buildout (2031) planning horizons using a WaterGEMS V8i model of the PD6 network as described in Section 3.

The piping layout within the development were sized to meet the greater requirement of Peak Hour Demands or Maximum Day Demand plus Fire Flow requirements. A detailed summary of demands is shown in Appendix A including the proposed pipe diameters for servicing the development.

4.1 SYSTEM PRESSURES

As outlined in the City of Hamilton WWWMP, the acceptable pressures under normal conditions range between 275 kPa (40 psi) and 690 kPa (100 psi). The modeling indicates that the expected service pressures range between approximately 284 kPa and 404 kPa for Phase 1 of the development and between 279 kPa and 455 kPa for ultimate buildout under all modeled scenarios. Modeled service pressures are summarized in Table 4-1 to Table 4-6. Detailed pipe and node result tables can be found in Appendix B.

Table 4-1: Simulated Pressures for Phase 1 with 50% TWL

SCENARIO	AVERAGE DAY (kPa)	MAXIMUM DAY (kPa)	PEAK HOUR (kPa)
2021	358 - 388	345 - 375	300 - 330
2031	351 - 380	333 - 363	284 - 314

Table 4-2: Simulated Pressures for Phase 1 with 70% TWL

SCENARIO	AVERAGE DAY (kPa)	MAXIMUM DAY (kPa)	PEAK HOUR (kPa)
2021	374 - 404	360 - 390	314 - 344
2031	365 - 395	347 - 377	298 - 328

Table 4-3: Simulated Pressures for Ultimate Buildout with 50% TWL

SCENARIO	AVERAGE DAY (kPa)	MAXIMUM DAY (kPa)	PEAK HOUR (kPa)
2021	356 - 419	343 - 406	298 - 360
2031	347 - 410	330 - 393	279 - 342

Table 4-4: Simulated Pressures for Ultimate Buildout with 70% TWL

SCENARIO	AVERAGE DAY (kPa)	MAXIMUM DAY (kPa)	PEAK HOUR (kPa)
2021	372 - 435	358 - 420	312 - 375
2031	361 - 419	345 - 407	293 - 356

Table 4-5: Simulated Pressures for Ultimate Buildout (Option 2) with 50% TWL

SCENARIO	AVERAGE DAY (kPa)	MAXIMUM DAY (kPa)	PEAK HOUR (kPa)
2021	357 - 439	344 - 426	296 - 380
2031	348 - 430	333 - 416	280 - 363

Table 4-6: Simulated Pressures for Ultimate Buildout (Option 2) with 70% TWL

SCENARIO	AVERAGE DAY (kPa)	MAXIMUM DAY (kPa)	PEAK HOUR (kPa)
2021	373 - 455	358 - 441	306 - 389
2031	362 - 445	347 - 430	294 - 378

The modelling results indicate that the expected service pressures within the development can meet the minimum pressure requirement of 275 kPa under all scenarios.

4.2 AVAILABLE FIRE FLOW

The minimum allowable pressure under Maximum Day Demand plus Fire Flow is 140 kPa (20 psi) at the location of the fire or anywhere else in the pressure district. The fire flow scenarios were simulated under Maximum Day Demand conditions for the 2021 and 2031 planning horizons.

Table 4-7 and Table 4-8 summarize the simulated available fire flows for Phase 1 and ultimate buildout of the proposed development under 2021 and 2031 planning horizons. A detailed analysis of fire flow availability at all nodes within the proposed development is included in Appendix C.

Table 4-7: Simulated Available Fire Flows at Hydrants Under Phase 1

SCENARIO	2021 MDD+FF AFF (L/S)	2031 MDD+FF AFF (L/S)
50% TWL	150 - 258	143 - 245
70% TWL	156 - 268	149 - 255
99% TWL	164 - 281	158 - 269

Note: 99% water level was considered as a sensitivity run and is not considered as a typical operation level.

Table 4-8: Simulated Available Fire Flows at Hydrants Under Ultimate Buildout

SCENARIO	2021 MDD+FF AFF (L/S)	2031 MDD+FF AFF (L/S)
50% TWL	190 - 256	183 - 243
70% TWL	196 - 266	189 - 253
99% TWL	205 - 279	198 - 267

Note: 99% water level was considered as a sensitivity run and is not considered as a typical operation level.

Table 4-9: Simulated Available Fire Flows at Hydrants Under Ultimate Buildout (Option 2)

SCENARIO	2021 MDD+FF AFF (L/S)	2031 MDD+FF AFF (L/S)
50% TWL	192 - 267	183 - 235
70% TWL	200 - 276	192 - 267
99% TWL	211 - 287	203 - 278

Note: 99% water level was considered as a sensitivity run and is not considered as a typical operation level.

Steady State modelling results of the fire flows indicate that the simulated pressures at ground level at all nodes within Pressure District 6 (PD6) are above 140 kPa under 2021 and 2031 Maximum Day Demand plus Fire Flow conditions.

As shown in Table 4-7, Table 4-8, and Table 4-9, the Available Fire Flows (AFF) were simulated below the Required Fire Flow of 250 L/s for industrial site under both 2021 and 2031 planning horizon. WSP ran additional simulation by increasing the tank water level at HDR05 to 99%, and the simulated AFFs increased by roughly 5%; however, they were still below the minimum fire flow requirement. The proposed site was still not able to achieve the targeted fire flow of 250 L/s; however, all hydrants were simulated with AFF higher than 150 L/s which is the highest possible required fire flow calculated using the OBC method.

To examine the impact on the fire flow capacity on the existing network with the addition of the proposed site, WSP ran the baseline scenario (without the proposed development) under 2021 and 2031 MDD+FF with 70% TWL. The simulated fire flow on the existing hydrants along Homestead Dr. and Airport Rd. ranged between 223 L/s and 269 L/s under 2021 planning horizon and 214 L/s and 257 L/s under 2031 planning horizon. These additional fire flow runs demonstrated that the development will cause the existing fire flows to drop by approximately 10%, and with the addition of looping, the simulated fire flow on a few existing hydrants on Airport Rd. increased. These results indicate that the addition of the proposed site has little impact on the existing network capacity to maintain the existing level of service for fire flows. Table 4-10 summarizes and compares the simulated fire flow on the existing hydrants under Baseline and Ultimate Buildout condition with 70% TWL in both 2021 and 2031 planning horizons.

Table 4-10: Simulated Available Fire Flows on Existing Hydrants with 70% TWL

SCENARIO	2021 MDD+FF AFF (L/S)	2031 MDD+FF AFF (L/S)
Baseline (without the development)	223 - 269	214 - 257
Ultimate Buildout	196 - 266	189 - 253
Ultimate Buildout – Option 2	200 - 276	192 - 267

4.2.1 MANUAL FIRE FLOW

WSP conducted manual fire flow runs to identify the limiting junctions within PD6. Table 4–11 summarizes the manual fire flow results and the number junctions below 140 kPa during 50% TWL.

Table 4-11: Manual Fire Flow Result Summary

JUNCTION ID	FIRE FLOW ASSIGNED (L/S)	PD6 PRESSURE RANGE (KPA)	NO. OF JUNCTION BELOW 140 KPA
H-187	250	-76 - 657	208
H-188	250	-105 - 657	208
H-189	250	-119 - 657	208
H-190	250	-105 - 657	208
H-191	250	-120 - 657	208
H-192	250	-146 - 657	209
H-193	250	-181 - 657	209
H-195	250	-55 - 657	215
H-197	250	-28 - 657	214

As shown in Table 4–11, the proposed hydrants cannot meet the required fire flow of 250 L/s under 50% TWL due to a number of junctions within PD6 fell below 140 kPa during the manual fire flow runs. These junctions can be found within the proposed development and the nearby Mount Hope development. The client confirms that the proposed development will be constructed with sprinkler systems to provide fire protection, which may reduce the required fire flow target used in this analysis. Detailed fire flow calculations need to be completed, and further analysis will be required to ensure the minimum HGL can be achieved for the sprinkler system once construction details become available.

4.3 TRANSIENT PRESSURES

According to the MECP Watermain Design Criteria, all watermains shall be designed so that pipes and joints are able to withstand the maximum operating pressure plus the surge pressure that would be created by stopping a water column moving at 0.6 m/s.

AWWA C900-compliant PVC pipe has a pressure rating of 235 psi (or greater) and this is consistent with the City of Hamilton's Specification for the Installation of Watermains (November 2018) that requires PVC pipe to be of Class 150 DR18. A PVC pipe with dimension ratio (DR) of 18 will experience a pressure surge of 240 kPa for a 0.6 m/s instantaneous flow velocity change (Joukowski).

The maximum operating pressure plus transient pressure is calculated as approximately 695 kPa (455 kPa + 240 kPa); well under 1620 kPa (235 psi) allowance. All pipe restraints and thrust blocks should be designed to a minimum 1030 kPa (150 psi) design pressure.

4.4 SYSTEM FLUSHING

A modeled flushing test was performed for the proposed water distribution network, under existing (2021) Average Day conditions for the Phase 1, full-buildout, and full-builtout (Option2) constructions to determine the achievable flushing velocities of the system. The MECP watermain design criterion requires a minimum flushing velocity of 0.8 m/s for pipes with diameter greater than or equal 150mm.

WaterGEMS software allows for testing of flushing by representing a modeled hydrant as a flow emitter with an emitter coefficient K equivalent to the components of the hydrant including the lateral, valve, bends and outlet. Hydrants were added to the model with a K value taken as $11.2 \text{ L/s/m}^{0.5}$ ($150 \text{ gpm/psi}^{0.5}$) which is the minimum value prescribed by the American Water Works Association (AWWA) standard for flow calculations through a single 60 mm (2.5") outlet.

For the flushing simulation under Phase 1, a total of four (4) proposed hydrants were selected within the site with one-port open. Based on the simulation, all watermains can meet the required flushing velocity of 0.8 m/s. To achieve this, it is required all proposed hydrants be flushed with a single port within the development. The achievable flushing velocity within the Phase 1 of the development ranges from 0.92 to 0.96 m/s.

For the flushing simulation under full-buildout, a total of seven (7) proposed hydrants were selected within the site with two-port open. Based on the simulation, all watermains can meet the required flushing velocity of 0.8 m/s. A blow-off valve was required at the dead end to Building A to flush the dead-ended pipe. To achieve this, it is required that all proposed hydrants be flushed with two ports opened within the development. The achievable flushing velocity within the Phase 1 of the development ranges from 0.88 to 1.83 m/s.

For the flushing simulation under full-buildout (Option 2), a total of nine (9) proposed hydrants were selected within the site with two-port open. Based on the simulation, all watermains can meet the required flushing velocity of 0.8 m/s. Blow-off valves were required at the dead end to flush the dead-ended pipes. To achieve this, it is required that all proposed hydrants be flushed with two ports opened within the development. The achievable flushing velocity within the Phase 1 of the development ranges from 0.81 to 1.54 m/s.

A detailed flushing report is provided in Appendix D.

5 CONCLUSIONS

The proposed watermain system for the 3054 Homestead Drive Development site can achieve hydraulic requirements as prescribed by the Ministry of the Environment, Conservation and Parks (MECP), and the City of Hamilton watermain design criteria as summarized below:

- 1 The service pressures under existing conditions (2021) and ultimate build-out conditions (2031) are expected to range between 284 kPa and 404 kPa for Phase 1 of the development and between 279 kPa and 455 kPa for ultimate buildout. The simulated pressures under all scenarios presented herein are within standards established by the MECP and City of Hamilton Guidelines.
- 2 Based on the City of Hamilton's fire flow policy, the required fire flow (RFF) for industrial site targets 250 L/s. In the 2021 planning horizon, the simulated AFF ranged between 150 L/s and 281 L/s under Phase 1 and between 190 L/s to 281 L/s under full-buildout. In 2031 planning horizon, the simulated AFF ranged between 143 L/s and 269 L/s under Phase 1 and between 183 L/s to 278 L/s under full-buildout. Additional simulations were completed with 99% TWL at HDR05, and the RFF target of 250 L/s cannot be maintained.

To examine the impact on the fire flow capacity on the existing network with the addition of the proposed site, WSP ran the baseline scenario under 2021 and 2031 MDD+FF with 70% TWL under both Phase 1 and full-buildout conditions. The results indicate that the addition of the proposed site has little impact on the existing network capacity to maintain the existing level of service for fire flows.

- 3 Under Maximum Day plus Fire Flow for existing (2021) and ultimate buildout (2031) conditions, the PD6 distribution system is able to maintain pressure above 140 kPa at ground level at all modeled nodes within the district;
- 4 When installing AWWA C900-compliant PVC pipe with a pressure rating of 235 psi (or greater), the watermains in the proposed development can withstand transient pressure created by stopping a water column moving at 0.6 m/s plus maximum operating pressure; and,
- 5 All proposed watermains can achieve a minimum flushing velocity of 0.8 m/s given the requirements outlined in Section 4.4.

These conclusions remain valid as long as the proposed water distribution system and the City's network configuration remain as described herein. If significant changes are contemplated, this analysis should be updated.

APPENDIX

A

DEMANDS AND PROPOSED SYSTEM LAYOUT

APPENDIX A
WATER DEMANDS

3054 Homestead Drive Develop ment

Demands




Population (Single Family)	3.39	ppu
Population (Townhomes)	2.45	ppu
Population (Apartments)	1.76	ppu
Density (Townhouses)	110.00	pha
Industrial	125	pha
Average Day Residential Demand	360	L/cap/day
Average Day Com mercial Demand	260	L/cap/day

Peaking Factors

Maximum Hour	3.00
Maximum Day	1.90

Demand Rate Calculation


Building	SINGLE FAMILY (No. of Units)	TOWNHOMES (No. of Units)	BUILDING AREA (Ha)	POPULATION	AVERAGE DAY (L/S)	MAX DAY (L/S)	PEAK HOUR (L/S)
Building C			3.44	430	1.29	2.46	3.88
Phase 1 Total			3.44	430	1.29	2.46	3.88
Building B			3.43	429	1.29	2.45	3.87
Building A			2.64	330	0.99	1.89	2.98
Building D			3.81	476	1.43	2.72	4.30
Total	0	0	13.32	1665	5.01	9.52	15.03



LEGEND:	
	SUBJECT LANDS
	EXISTING PROPERTY LINES
	PROPOSED BUILDING
	MAN DOOR
	OVERHEAD DOOR

DEVELOPMENT STATISTICS Airside Industrial (M7) Zone		
Item	Required	Proposed
Permitted Uses	Warehouse & Office	Warehouse & Office
Min. Lot Area	4,000.00 m ²	313,822.42 m ²
No. of Buildings	N/A	4 Buildings
	3.0 m	New Service Road: 56.22 m (Building A) East Cargo Road: 33.00 m (Building A) Homestead Road: 94.84 m (Building C) Street 'A': 3.00 m (Building Nos. A-C)
Min. Yard Abutting a Street	TBD	TBD
Max. Building Height	10%	11.87% (Excluding ROW & NHS Compensation)
Landscaping	3.0 m	3.0 m
Min. Landscaped Strip		
Parking		
Warehouse	1 space/ 30m ² of Office Use = 3,485.90 m ² /30 =116 spaces	911 Typical Spaces 243 Truck Level Doors 30 Trailer Parking Spaces Total: 1,184 spaces
Long Term Bicycle Parking	5% of Required Spaces = 5.8 spaces	TBD

DEVELOPMENT STATISTICS: GFA	
Item	Proposed
Building 'A'	33,468.93 m ² (360,257 ft ²)
Building 'B'	38,268.75 m ² (411,921 ft ²)
Building 'C'	26,562.68 m ² (285,918 ft ²)
Building 'D'	31,250.96 m ² (336,382 ft ²)
Total	129,551.32 m ² (1,394,478 ft ²)



URBAN SOLUTIONS
PLANNING & LAND DEVELOPMENT
3 STUDEBAKER PLACE, UNIT 1
HAMILTON, ON L8L 0C8
905-546-1087 URBANSOLUTIONS.INFO

PROJECT:

3054 HOMESTEAD DRIVE, 9174 & 9166 AIRPORT ROAD WEST
City of Hamilton

CLIENT:

FENGATE HOMESTEAD HOLDINGS LP

TITLE:

CONCEPT PLAN

U/S FILE NUMBER:	SHEET NUMBER:
413-21	1




Figure A1 – Proposed Phase 1 3054 Homestead Drive Development System Layout Highlighted in Red




Figure A2 – Proposed 3054 Homestead Drive Development System Layout Highlighted in Red




Figure A3 – Proposed 3054 Homestead Drive Development (Option 2) System Layout Highlighted in Red




Figure A4 – Proposed Phase 1 3054 Homestead Drive Development System Layout with Junction and Hydrant IDs




Figure A5 – Proposed Phase 1 3054 Homestead Drive Development System Layout with Pipe IDs




Figure A6 – Proposed 3054 Homestead Drive Development System Layout with Junction and Hydrant IDs




Figure A7 – Proposed 3054 Homestead Drive Development System Layout with Pipe IDs




Figure A8 – Proposed 3054 Homestead Drive Development System (Option 2) Layout with Junction and Hydrant IDs




Figure A9 – Proposed 3054 Homestead Drive Development (Option 2) System Layout with Pipe IDs

APPENDIX

B

PIPE AND JUNCTION TABLES

2021 ADD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	271.99	358
J-1103	235.24	0.00	271.98	360
HS-J-1123	234.98	1.29	271.99	362
HS-J-1115	234.91	0.00	271.99	363
HS-J-1124	234.85	0.00	271.99	363
HS-J-1117	234.54	0.00	271.99	367
HS-J-1120	234.43	0.00	271.99	368
HS-J-1119	232.92	0.00	271.99	382
HS-J-1118	232.70	0.00	271.99	385
J-1129	232.36	0.00	271.99	388
Sum of Demand:		1.29	Min	358
			Max	388

2021 MDD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	270.70	345
J-1103	235.24	0.00	270.69	347
HS-J-1123	234.98	2.46	270.70	350
HS-J-1115	234.91	0.00	270.70	350
HS-J-1124	234.85	0.00	270.70	351
HS-J-1117	234.54	0.00	270.70	354
HS-J-1120	234.43	0.00	270.70	355
HS-J-1119	232.92	0.00	270.70	370
HS-J-1118	232.70	0.00	270.70	372
J-1129	232.36	0.00	270.71	375
Sum of Demand:		2.46	Min	345
			Max	375

2021 PHD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	266.04	300
J-1103	235.24	0.00	266.07	302
HS-J-1123	234.98	3.88	266.04	304
HS-J-1115	234.91	0.00	266.04	305
HS-J-1124	234.85	0.00	266.04	305
HS-J-1117	234.54	0.00	266.04	308
HS-J-1120	234.43	0.00	266.04	309
HS-J-1119	232.92	0.00	266.05	324
HS-J-1118	232.70	0.00	266.05	326
J-1129	232.36	0.00	266.05	330
Sum of Demand:		3.88	Min	300
			Max	330

2021 ADD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
P-879	HS-J-1118	H-187	6.10	150	100	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	-1.00	0.02	0.00
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	-1.00	0.02	0.00
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	-1.00	0.02	0.00
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	-1.00	0.02	0.00
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	-1.00	0.02	0.00
HS-P-883	HS-J-1118	J-1129	84.12	300	120	-1.00	0.02	0.00
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	-1.00	0.02	0.00
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	1.00	0.02	0.00

2021 MDD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
P-879	HS-J-1118	H-187	6.10	150	100	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	-2.46	0.03	0.01
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	-2.46	0.03	0.01
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	-2.46	0.03	0.01
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	-2.46	0.03	0.01
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	-2.46	0.03	0.01
HS-P-883	HS-J-1118	J-1129	84.12	300	120	-2.46	0.03	0.01
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	-2.46	0.03	0.01
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	2.46	0.03	0.01

2021 PHD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
P-879	HS-J-1118	H-187	6.10	150	100	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	-3.88	0.05	0.02
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	-3.88	0.05	0.02
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	-3.88	0.05	0.02
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	-3.88	0.05	0.02
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	-3.88	0.05	0.02
HS-P-883	HS-J-1118	J-1129	84.12	300	120	-3.88	0.05	0.02
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	-3.88	0.05	0.02
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	3.88	0.05	0.02



Junctions Tables
Phase 1 - 50% TWL

221-10826-00

2031 ADD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	271.2	351
J-1103	235.24	0.00	271.2	352
HS-J-1123	234.98	1.29	271.2	355
HS-J-1115	234.91	0.00	271.23	355
HS-J-1124	234.85	0.00	271.23	356
HS-J-1117	234.54	0.00	271.23	359
HS-J-1120	234.43	0.00	271.23	360
HS-J-1119	232.92	0.00	271.23	375
HS-J-1118	232.70	0.00	271.23	377
J-1129	232.36	0.00	271.23	380
Sum of Demand:		1.29	Min	351
			Max	380

2031 MDD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	269.42	333
J-1103	235.24	0.00	269.41	334
HS-J-1123	234.98	2.45	269.42	337
HS-J-1115	234.91	0.00	269.42	338
HS-J-1124	234.85	0.00	269.42	338
HS-J-1117	234.54	0.00	269.43	341
HS-J-1120	234.43	0.00	269.42	342
HS-J-1119	232.92	0.00	269.43	357
HS-J-1118	232.70	0.00	269.43	359
J-1129	232.36	0.00	269.43	363
Sum of Demand:		2.45	Min	333
			Max	363

2031 PHD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	264.40	284
J-1103	235.24	0.00	264.43	286
HS-J-1123	234.98	3.88	264.39	288
HS-J-1115	234.91	0.00	264.39	289
HS-J-1124	234.85	0.00	264.40	289
HS-J-1117	234.54	0.00	264.40	292
HS-J-1120	234.43	0.00	264.39	293
HS-J-1119	232.92	0.00	264.40	308
HS-J-1118	232.70	0.00	264.40	310
J-1129	232.36	0.00	264.40	314
Sum of Demand:		3.88	Min	284
			Max	314



Pipe Tables
Phase 1 - 50% TWL

221-10826-00

2031 ADD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
P-879	HS-J-1118	H-187	6.10	150	100	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	-1.29	0.02	0.00
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	-1.29	0.02	0.00
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	-1.29	0.02	0.00
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	-1.29	0.02	0.00
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	-1.29	0.02	0.00
HS-P-883	HS-J-1118	J-1129	84.12	300	120	-1.29	0.02	0.00
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	-1.29	0.02	0.00
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	1.29	0.02	0.00

2031 MDD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
P-879	HS-J-1118	H-187	6.10	150	100	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	-2.45	0.03	0.01
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	-2.45	0.03	0.01
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	-2.45	0.03	0.01
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	-2.45	0.03	0.01
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	-2.45	0.03	0.01
HS-P-883	HS-J-1118	J-1129	84.12	300	120	-2.45	0.03	0.01
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	-2.45	0.03	0.01
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	2.45	0.03	0.01

2031 PHD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
P-879	HS-J-1118	H-187	6.10	150	100	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	-3.88	0.05	0.02
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	-3.88	0.05	0.02
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	-3.88	0.05	0.02
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	-3.88	0.05	0.02
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	-3.88	0.05	0.02
HS-P-883	HS-J-1118	J-1129	84.12	300	120	-3.88	0.05	0.02
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	-3.88	0.05	0.02
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	3.88	0.05	0.02

2021 ADD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	273.61	374
J-1103	235.24	0.00	273.59	375
HS-J-1123	234.98	1.29	273.60	378
HS-J-1115	234.91	0.00	273.60	379
HS-J-1124	234.85	0.00	273.61	379
HS-J-1117	234.54	0.00	273.61	382
HS-J-1120	234.43	0.00	273.60	383
HS-J-1119	232.92	0.00	273.61	398
HS-J-1118	232.70	0.00	273.61	400
J-1129	232.36	0.00	273.61	404
Sum of Demand:		1.29	Min	374
			Max	404

2021 MDD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	272.19	360
J-1103	235.24	0.00	272.17	361
HS-J-1123	234.98	2.46	272.19	364
HS-J-1115	234.91	0.00	272.19	365
HS-J-1124	234.85	0.00	272.19	365
HS-J-1117	234.54	0.00	272.19	368
HS-J-1120	234.43	0.00	272.19	370
HS-J-1119	232.92	0.00	272.19	384
HS-J-1118	232.70	0.00	272.19	387
J-1129	232.36	0.00	272.19	390
Sum of Demand:		2.46	Min	360
			Max	390

2021 PHD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	267.48	314
J-1103	235.24	0.00	267.51	316
HS-J-1123	234.98	3.88	267.48	318
HS-J-1115	234.91	0.00	267.48	319
HS-J-1124	234.85	0.00	267.49	319
HS-J-1117	234.54	0.00	267.49	322
HS-J-1120	234.43	0.00	267.48	323
HS-J-1119	232.92	0.00	267.49	338
HS-J-1118	232.70	0.00	267.49	341
J-1129	232.36	0.00	267.49	344
Sum of Demand:		3.88	Min	314
			Max	344

2021 ADD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
P-879	HS-J-1118	H-187	6.10	150	100	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	-1.29	0.02	0.00
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	-1.29	0.02	0.00
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	-1.29	0.02	0.00
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	-1.29	0.02	0.00
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	-1.29	0.02	0.00
HS-P-883	HS-J-1118	J-1129	84.12	300	120	-1.29	0.02	0.00
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	-1.29	0.02	0.00
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	1.29	0.02	0.00

2021 MDD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
P-879	HS-J-1118	H-187	6.10	150	100	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	-2.46	0.03	0.01
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	-2.46	0.03	0.01
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	-2.46	0.03	0.01
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	-2.46	0.03	0.01
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	-2.46	0.03	0.01
HS-P-883	HS-J-1118	J-1129	84.12	300	120	-2.46	0.03	0.01
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	-2.46	0.03	0.01
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	2.46	0.03	0.01

2021 PHD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
P-879	HS-J-1118	H-187	6.10	150	100	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	-3.88	0.05	0.02
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	-3.88	0.05	0.02
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	-3.88	0.05	0.02
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	-3.88	0.05	0.02
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	-3.88	0.05	0.02
HS-P-883	HS-J-1118	J-1129	84.12	300	120	-3.88	0.05	0.02
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	-3.88	0.05	0.02
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	3.88	0.05	0.02



Junctions Tables
Phase 1 - 70% TWL

221-10826-00

2031 ADD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	272.71	365
J-1103	235.24	0.00	272.70	367
HS-J-1123	234.98	1.29	272.71	369
HS-J-1115	234.91	0.00	272.71	370
HS-J-1124	234.85	0.00	272.71	370
HS-J-1117	234.54	0.00	272.71	374
HS-J-1120	234.43	0.00	272.71	375
HS-J-1119	232.92	0.00	272.71	389
HS-J-1118	232.70	0.00	272.71	392
J-1129	232.36	0.00	272.71	395
Sum of Demand:		1.29	Min	365
			Max	395

2031 MDD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	270.90	347
J-1103	235.24	0.00	270.88	349
HS-J-1123	234.98	2.45	270.90	352
HS-J-1115	234.91	0.00	270.90	352
HS-J-1124	234.85	0.00	270.90	353
HS-J-1117	234.54	0.00	270.90	356
HS-J-1120	234.43	0.00	270.90	357
HS-J-1119	232.92	0.00	270.90	372
HS-J-1118	232.70	0.00	270.90	374
J-1129	232.36	0.00	270.90	377
Sum of Demand:		2.45	Min	347
			Max	377

2031 PHD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	265.87	298
J-1103	235.24	0.00	265.91	300
HS-J-1123	234.98	3.88	265.87	302
HS-J-1115	234.91	0.00	265.87	303
HS-J-1124	234.85	0.00	265.87	304
HS-J-1117	234.54	0.00	265.88	307
HS-J-1120	234.43	0.00	265.87	308
HS-J-1119	232.92	0.00	265.88	323
HS-J-1118	232.70	0.00	265.88	325
J-1129	232.36	0.00	265.88	328
Sum of Demand:		3.88	Min	298
			Max	328



Pipe Tables
Phase 1 - 70% TWL

221-10826-00

2031 ADD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
P-879	HS-J-1118	H-187	6.10	150	100	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	-1.29	0.02	0.00
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	-1.29	0.02	0.00
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	-1.29	0.02	0.00
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	-1.29	0.02	0.00
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	-1.29	0.02	0.00
HS-P-883	HS-J-1118	J-1129	84.12	300	120	-1.29	0.02	0.00
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	-1.29	0.02	0.00
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	1.29	0.02	0.00

2031 MDD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
P-879	HS-J-1118	H-187	6.10	150	100	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	-2.45	0.03	0.01
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	-2.45	0.03	0.01
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	-2.45	0.03	0.01
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	-2.45	0.03	0.01
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	-2.45	0.03	0.01
HS-P-883	HS-J-1118	J-1129	84.12	300	120	-2.45	0.03	0.01
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	-2.45	0.03	0.01
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	2.45	0.03	0.01

2031 PHD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
P-879	HS-J-1118	H-187	6.10	150	100	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	-3.88	0.05	0.02
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	-3.88	0.05	0.02
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	-3.88	0.05	0.02
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	-3.88	0.05	0.02
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	-3.88	0.05	0.02
HS-P-883	HS-J-1118	J-1129	84.12	300	120	-3.88	0.05	0.02
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	-3.88	0.05	0.02
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	3.88	0.05	0.02



Junctions Tables
Full Buildout - 50% TWL

221-10826-00

2021 ADD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	271.82	356
J-1103	235.24	0.00	271.82	358
HS-J-1123	234.98	1.29	271.81	360
HS-J-1115	234.91	0.00	271.82	361
HS-J-1124	234.85	0.00	271.82	362
HS-J-1117	234.54	0.00	271.82	365
HS-J-1120	234.43	0.00	271.82	366
HS-J-1102	234.23	0.00	271.82	368
HS-J-1121	234.00	1.43	271.81	370
HS-J-1108	233.73	0.00	271.81	373
HS-J-1110	233.44	0.99	271.81	376
HS-J-1107	233.41	0.00	271.81	376
HS-J-1109	232.98	1.29	271.81	380
HS-J-1122	232.97	0.00	271.81	380
HS-J-1119	232.92	0.00	271.82	381
HS-J-1118	232.70	0.00	271.82	383
J-1129	232.36	0.00	271.83	386
HS-J-1106	232.22	0.00	271.81	388
HS-J-1103	229.11	0.00	271.81	418
HS-J-1104	229.04	0.00	271.81	419
HS-J-1105	229.00	0.00	271.81	419
Sum of Demand:		5.00	Min	356
			Max	419



Junctions Tables
Full Buildout - 50% TWL

221-10826-00

2021 MDD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	270.45	343
J-1103	235.24	0.00	270.45	345
HS-J-1123	234.98	2.45	270.44	347
HS-J-1115	234.91	0.00	270.44	348
HS-J-1124	234.85	0.00	270.45	348
HS-J-1117	234.54	0.00	270.46	352
HS-J-1120	234.43	0.00	270.44	352
HS-J-1102	234.00	1.89	270.44	354
HS-J-1121	233.73	0.00	270.44	357
HS-J-1108	233.44	2.46	270.44	359
HS-J-1110	233.41	0.00	270.44	362
HS-J-1107	232.98	2.72	270.44	362
HS-J-1109	232.92	0.00	270.44	367
HS-J-1122	232.70	0.00	270.44	367
HS-J-1119	232.36	0.00	270.46	367
HS-J-1118	232.22	0.00	270.46	370
J-1129	229.11	0.00	270.47	373
HS-J-1106	229.04	0.00	270.44	374
HS-J-1103	229.00	0.00	270.44	405
HS-J-1104	228.18	0.00	270.44	405
HS-J-1105	227.00	0.00	270.44	406
Sum of Demand:		9.52	Min	343
			Max	406



Junctions Tables
Full Buildout - 50% TWL

221-10826-00

2021 PHD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1102	235.40	0.00	265.83	309
HS-J-1122	235.24	0.00	265.82	321
HS-J-1116	234.98	3.88	265.81	298
J-1103	234.91	0.00	265.83	299
HS-J-1123	234.85	0.00	265.81	302
HS-J-1115	234.54	0.00	265.81	302
HS-J-1124	234.43	0.00	265.82	303
HS-J-1117	234.00	4.30	265.83	306
HS-J-1120	233.73	0.00	265.81	307
HS-J-1121	233.44	2.98	265.81	311
HS-J-1108	233.41	0.00	265.81	314
HS-J-1110	232.98	3.87	265.81	317
HS-J-1107	232.92	0.00	265.82	317
HS-J-1109	232.70	0.00	265.81	321
HS-J-1119	232.36	0.00	265.83	322
HS-J-1118	232.22	0.00	265.83	324
J-1129	229.11	0.00	265.84	328
HS-J-1106	229.04	0.00	265.82	329
HS-J-1103	229.00	0.00	265.82	359
HS-J-1104	228.18	0.00	265.82	360
HS-J-1105	227.00	0.00	265.82	360
Sum of Demand:		15.03	Min	298
			Max	360

2021 ADD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
HS-P-870	J-1103	HS-J-1102	83.52	300.00	120.00	1.41	0.02	0.00
HS-P-871	HS-J-1102	HS-J-1122	86.87	300.00	120.00	1.41	0.02	0.00
HS-P-872	HS-J-1122	HS-J-1107	23.77	300.00	120.00	1.41	0.02	0.00
HS-P-873	HS-J-1103	HS-J-1104	11.28	300.00	120.00	0.00	0.00	0.00
HS-P-874	HS-J-1103	HS-J-1105	88.09	300.00	120.00	0.00	0.00	0.00
HS-P-875	HS-J-1105	HS-J-1106	178.92	300.00	120.00	0.00	0.00	0.00
HS-P-876	HS-J-1106	HS-J-1107	78.33	300.00	120.00	0.00	0.00	0.00
HS-P-877	HS-J-1107	HS-J-1108	109.42	300.00	120.00	1.41	0.02	0.00
HS-P-878	HS-J-1108	HS-J-1121	63.70	300.00	120.00	0.42	0.01	0.00
HS-P-879	HS-J-1121	HS-J-1109	70.41	300.00	120.00	1.29	0.02	0.00
HS-P-883	HS-J-1118	J-1129	84.12	300.00	120.00	-3.60	0.05	0.02
HS-P-886	HS-J-1121	HS-J-1120	80.47	300.00	120.00	-2.31	0.03	0.01
HS-P-887	HS-J-1120	HS-J-1115	28.96	300.00	120.00	-3.60	0.05	0.02
HS-P-888	HS-J-1115	HS-J-1116	130.15	300.00	120.00	-3.60	0.05	0.02
HS-P-889	HS-J-1116	HS-J-1124	53.34	300.00	120.00	-3.60	0.05	0.02
HS-P-890	HS-J-1124	HS-J-1117	179.22	300.00	120.00	-3.60	0.05	0.02
HS-P-891	HS-J-1117	HS-J-1119	128.32	300.00	120.00	-3.60	0.05	0.02
HS-P-892	HS-J-1119	HS-J-1118	54.86	300.00	120.00	-3.60	0.05	0.02
HS-P-893	HS-J-1120	HS-J-1123	30.18	300.00	120.00	1.29	0.02	0.00
HS-P-894	HS-J-1108	HS-J-1110	7.92	300.00	120.00	0.99	0.01	0.00
P-879	HS-J-1118	H-187	6.10	150.00	100.00	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150.00	100.00	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150.00	100.00	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150.00	100.00	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150.00	100.00	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150.00	100.00	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150.00	100.00	0.00	0.00	0.00

2021 MDD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
HS-P-870	J-1103	HS-J-1102	83.52	300.00	120.00	3.84	0.05	0.02
HS-P-871	HS-J-1102	HS-J-1122	86.87	300.00	120.00	3.84	0.05	0.02
HS-P-872	HS-J-1122	HS-J-1107	23.77	300.00	120.00	3.84	0.05	0.02
HS-P-873	HS-J-1103	HS-J-1104	11.28	300.00	120.00	0.00	0.00	0.00
HS-P-874	HS-J-1103	HS-J-1105	88.09	300.00	120.00	0.00	0.00	0.00
HS-P-875	HS-J-1105	HS-J-1106	178.92	300.00	120.00	0.00	0.00	0.00
HS-P-876	HS-J-1106	HS-J-1107	78.33	300.00	120.00	0.00	0.00	0.00
HS-P-877	HS-J-1107	HS-J-1108	109.42	300.00	120.00	3.84	0.05	0.02
HS-P-878	HS-J-1108	HS-J-1121	63.70	300.00	120.00	1.95	0.03	0.01
HS-P-879	HS-J-1121	HS-J-1109	70.41	300.00	120.00	2.45	0.03	0.01
HS-P-883	HS-J-1118	J-1129	84.12	300.00	120.00	-5.68	0.08	0.04
HS-P-886	HS-J-1121	HS-J-1120	80.47	300.00	120.00	-3.22	0.05	0.01
HS-P-887	HS-J-1120	HS-J-1115	28.96	300.00	120.00	-5.68	0.08	0.04
HS-P-888	HS-J-1115	HS-J-1116	130.15	300.00	120.00	-5.68	0.08	0.04
HS-P-889	HS-J-1116	HS-J-1124	53.34	300.00	120.00	-5.68	0.08	0.04
HS-P-890	HS-J-1124	HS-J-1117	179.22	300.00	120.00	-5.68	0.08	0.04
HS-P-891	HS-J-1117	HS-J-1119	128.32	300.00	120.00	-5.68	0.08	0.04
HS-P-892	HS-J-1119	HS-J-1118	54.86	300.00	120.00	-5.68	0.08	0.04
HS-P-893	HS-J-1120	HS-J-1123	30.18	300.00	120.00	2.46	0.03	0.01
HS-P-894	HS-J-1108	HS-J-1110	7.92	300.00	120.00	1.89	0.03	0.00
P-879	HS-J-1118	H-187	6.10	150.00	100.00	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150.00	100.00	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150.00	100.00	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150.00	100.00	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150.00	100.00	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150.00	100.00	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150.00	100.00	0.00	0.00	0.00

2021 PHD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
HS-P-870	J-1103	HS-J-1102	83.52	300.00	120.00	8.68	0.12	0.08
HS-P-871	HS-J-1102	HS-J-1122	86.87	300.00	120.00	8.68	0.12	0.08
HS-P-872	HS-J-1122	HS-J-1107	23.77	300.00	120.00	8.68	0.12	0.08
HS-P-873	HS-J-1103	HS-J-1104	11.28	300.00	120.00	0.00	0.00	0.00
HS-P-874	HS-J-1103	HS-J-1105	88.09	300.00	120.00	0.00	0.00	0.00
HS-P-875	HS-J-1105	HS-J-1106	178.92	300.00	120.00	0.00	0.00	0.00
HS-P-876	HS-J-1106	HS-J-1107	78.33	300.00	120.00	0.00	0.00	0.00
HS-P-877	HS-J-1107	HS-J-1108	109.42	300.00	120.00	8.68	0.12	0.08
HS-P-878	HS-J-1108	HS-J-1121	63.70	300.00	120.00	5.70	0.08	0.04
HS-P-879	HS-J-1121	HS-J-1109	70.41	300.00	120.00	3.87	0.05	0.02
HS-P-883	HS-J-1118	J-1129	84.12	300.00	120.00	-6.35	0.09	0.05
HS-P-886	HS-J-1121	HS-J-1120	80.47	300.00	120.00	-2.47	0.03	0.01
HS-P-887	HS-J-1120	HS-J-1115	28.96	300.00	120.00	-6.35	0.09	0.04
HS-P-888	HS-J-1115	HS-J-1116	130.15	300.00	120.00	-6.35	0.09	0.05
HS-P-889	HS-J-1116	HS-J-1124	53.34	300.00	120.00	-6.35	0.09	0.05
HS-P-890	HS-J-1124	HS-J-1117	179.22	300.00	120.00	-6.35	0.09	0.05
HS-P-891	HS-J-1117	HS-J-1119	128.32	300.00	120.00	-6.35	0.09	0.05
HS-P-892	HS-J-1119	HS-J-1118	54.86	300.00	120.00	-6.35	0.09	0.05
HS-P-893	HS-J-1120	HS-J-1123	30.18	300.00	120.00	3.88	0.05	0.02
HS-P-894	HS-J-1108	HS-J-1110	7.92	300.00	120.00	2.98	0.04	0.01
P-879	HS-J-1118	H-187	6.10	150.00	100.00	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150.00	100.00	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150.00	100.00	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150.00	100.00	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150.00	100.00	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150.00	100.00	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150.00	100.00	0.00	0.00	0.00



Junctions Tables
Full Buildout - 50% TWL

221-10826-00

2031 ADD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	270.86	347
J-1103	235.24	0.00	270.86	349
HS-J-1123	234.98	1.29	270.86	351
HS-J-1115	234.91	0.00	270.86	352
HS-J-1124	234.85	0.00	270.86	352
HS-J-1117	234.54	0.00	270.87	356
HS-J-1120	234.43	0.00	270.86	357
HS-J-1102	234.23	0.00	270.86	358
HS-J-1121	234.00	1.43	270.86	361
HS-J-1108	233.73	0.00	270.86	363
HS-J-1110	233.44	0.99	270.86	366
HS-J-1107	233.41	0.00	270.86	367
HS-J-1109	232.98	1.29	270.86	371
HS-J-1122	232.97	0.00	270.86	371
HS-J-1119	232.92	0.00	270.87	371
HS-J-1118	232.70	0.00	270.87	374
J-1129	232.36	0.00	270.87	377
HS-J-1106	232.22	0.00	270.86	378
HS-J-1103	229.11	0.00	270.86	409
HS-J-1104	229.04	0.00	270.86	409
HS-J-1105	229.00	0.00	270.86	410
Sum of Demand:		5.00	Min	347
			Max	410



Junctions Tables
Full Buildout - 50% TWL

221-10826-00

2031 MDD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	269.16	330
J-1103	235.24	0.00	269.15	332
HS-J-1123	234.98	2.45	269.15	334
HS-J-1115	234.91	0.00	269.15	335
HS-J-1124	234.85	0.00	269.16	336
HS-J-1117	234.54	0.00	269.16	339
HS-J-1120	234.43	0.00	269.15	340
HS-J-1102	234.23	0.00	269.15	342
HS-J-1121	234.00	1.89	269.15	344
HS-J-1108	233.73	0.00	269.15	347
HS-J-1110	233.44	2.46	269.15	349
HS-J-1107	233.41	0.00	269.15	350
HS-J-1109	232.98	2.72	269.15	354
HS-J-1122	232.97	0.00	269.15	354
HS-J-1119	232.92	0.00	269.17	355
HS-J-1118	232.70	0.00	269.17	357
J-1129	232.36	0.00	269.17	360
HS-J-1106	232.22	0.00	269.15	361
HS-J-1103	229.11	0.00	269.15	392
HS-J-1104	229.04	0.00	269.15	393
HS-J-1105	229.00	0.00	269.15	393

Sum of Demand:

9.52

Min

330

Max

393



Junctions Tables
Full Buildout - 50% TWL

221-10826-00

2031 PHD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	263.89	279
J-1103	235.24	0.00	263.91	281
HS-J-1123	234.98	3.88	263.88	283
HS-J-1115	234.91	0.00	263.88	284
HS-J-1124	234.85	0.00	263.89	284
HS-J-1117	234.54	0.00	263.90	287
HS-J-1120	234.43	0.00	263.88	288
HS-J-1102	234.23	0.00	263.90	290
HS-J-1121	234.00	4.30	263.88	292
HS-J-1108	233.73	0.00	263.89	295
HS-J-1110	233.44	2.98	263.89	298
HS-J-1107	233.41	0.00	263.89	298
HS-J-1109	232.98	3.87	263.88	302
HS-J-1122	232.97	0.00	263.90	303
HS-J-1119	232.92	0.00	263.91	303
HS-J-1118	232.70	0.00	263.91	305
J-1129	232.36	0.00	263.91	309
HS-J-1106	232.22	0.00	263.89	310
HS-J-1103	229.11	0.00	263.89	340
HS-J-1104	229.04	0.00	263.89	341
HS-J-1105	229.00	0.00	263.89	342
Sum of Demand:		15.03	Min	279
			Max	342



Pipe Tables
Full Buildout - 50% TWL

221-10826-00

2031 ADD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
HS-P-873	HS-J-1103	HS-J-1104	11.28	300.00	120.00	0.00	0.00	0.00
HS-P-876	HS-J-1106	HS-J-1107	78.33	300.00	120.00	0.00	0.00	0.00
HS-P-874	HS-J-1103	HS-J-1105	88.09	300.00	120.00	0.00	0.00	0.00
HS-P-875	HS-J-1105	HS-J-1106	178.92	300.00	120.00	0.00	0.00	0.00
P-879	HS-J-1118	H-187	6.10	150.00	100.00	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150.00	100.00	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150.00	100.00	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150.00	100.00	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150.00	100.00	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150.00	100.00	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150.00	100.00	0.00	0.00	0.00
HS-P-878	HS-J-1108	HS-J-1121	63.70	300.00	120.00	0.42	0.01	0.00
HS-P-894	HS-J-1108	HS-J-1110	7.92	300.00	120.00	0.99	0.01	0.00
HS-P-893	HS-J-1120	HS-J-1123	30.18	300.00	120.00	1.29	0.02	0.00
HS-P-879	HS-J-1121	HS-J-1109	70.41	300.00	120.00	1.29	0.02	0.00
HS-P-886	HS-J-1121	HS-J-1120	80.47	300.00	120.00	-2.31	0.03	0.01
HS-P-870	J-1103	HS-J-1102	83.52	300.00	120.00	1.41	0.02	0.00
HS-P-877	HS-J-1107	HS-J-1108	109.42	300.00	120.00	1.41	0.02	0.00
HS-P-871	HS-J-1102	HS-J-1122	86.87	300.00	120.00	1.41	0.02	0.00
HS-P-872	HS-J-1122	HS-J-1107	23.77	300.00	120.00	1.41	0.02	0.00
HS-P-891	HS-J-1117	HS-J-1119	128.32	300.00	120.00	-3.60	0.05	0.02
HS-P-888	HS-J-1115	HS-J-1116	130.15	300.00	120.00	-3.60	0.05	0.02
HS-P-887	HS-J-1120	HS-J-1115	28.96	300.00	120.00	-3.60	0.05	0.02
HS-P-889	HS-J-1116	HS-J-1124	53.34	300.00	120.00	-3.60	0.05	0.02
HS-P-892	HS-J-1119	HS-J-1118	54.86	300.00	120.00	-3.60	0.05	0.02
HS-P-890	HS-J-1124	HS-J-1117	179.22	300.00	120.00	-3.60	0.05	0.02
HS-P-883	HS-J-1118	J-1129	84.12	300.00	120.00	-3.60	0.05	0.02



Pipe Tables
Full Buildout - 50% TWL

221-10826-00

2031 MDD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
HS-P-873	HS-J-1103	HS-J-1104	11.28	300.00	120.00	0.00	0.00	0.00
HS-P-876	HS-J-1106	HS-J-1107	78.33	300.00	120.00	0.00	0.00	0.00
HS-P-874	HS-J-1103	HS-J-1105	88.09	300.00	120.00	0.00	0.00	0.00
HS-P-875	HS-J-1105	HS-J-1106	178.92	300.00	120.00	0.00	0.00	0.00
P-879	HS-J-1118	H-187	6.10	150.00	100.00	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150.00	100.00	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150.00	100.00	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150.00	100.00	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150.00	100.00	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150.00	100.00	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150.00	100.00	0.00	0.00	0.00
HS-P-878	HS-J-1108	HS-J-1121	63.70	300.00	120.00	1.39	0.02	0.00
HS-P-894	HS-J-1108	HS-J-1110	7.92	300.00	120.00	2.46	0.03	0.01
HS-P-893	HS-J-1120	HS-J-1123	30.18	300.00	120.00	2.45	0.03	0.01
HS-P-879	HS-J-1121	HS-J-1109	70.41	300.00	120.00	2.72	0.04	0.01
HS-P-886	HS-J-1121	HS-J-1120	80.47	300.00	120.00	-3.22	0.05	0.01
HS-P-870	J-1103	HS-J-1102	83.52	300.00	120.00	3.85	0.05	0.02
HS-P-877	HS-J-1107	HS-J-1108	109.42	300.00	120.00	3.85	0.05	0.02
HS-P-871	HS-J-1102	HS-J-1122	86.87	300.00	120.00	3.85	0.05	0.02
HS-P-872	HS-J-1122	HS-J-1107	23.77	300.00	120.00	3.85	0.05	0.02
HS-P-891	HS-J-1117	HS-J-1119	128.32	300.00	120.00	-5.67	0.08	0.04
HS-P-888	HS-J-1115	HS-J-1116	130.15	300.00	120.00	-5.67	0.08	0.04
HS-P-887	HS-J-1120	HS-J-1115	28.96	300.00	120.00	-5.67	0.08	0.04
HS-P-889	HS-J-1116	HS-J-1124	53.34	300.00	120.00	-5.67	0.08	0.04
HS-P-892	HS-J-1119	HS-J-1118	54.86	300.00	120.00	-5.67	0.08	0.04
HS-P-890	HS-J-1124	HS-J-1117	179.22	300.00	120.00	-5.67	0.08	0.04
HS-P-883	HS-J-1118	J-1129	84.12	300.00	120.00	-5.67	0.08	0.04



Pipe Tables
Full Buildout - 50% TWL

221-10826-00

2031 PHD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
HS-P-894	HS-J-1108	HS-J-1110	7.92	300.00	120.00	2.98	0.04	0.01
HS-P-873	HS-J-1103	HS-J-1104	11.28	300.00	120.00	0.00	0.00	0.00
HS-P-876	HS-J-1106	HS-J-1107	78.33	300.00	120.00	0.00	0.00	0.00
HS-P-874	HS-J-1103	HS-J-1105	88.09	300.00	120.00	0.00	0.00	0.00
HS-P-875	HS-J-1105	HS-J-1106	178.92	300.00	120.00	0.00	0.00	0.00
P-879	HS-J-1118	H-187	6.10	150.00	100.00	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150.00	100.00	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150.00	100.00	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150.00	100.00	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150.00	100.00	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150.00	100.00	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150.00	100.00	0.00	0.00	0.00
HS-P-878	HS-J-1108	HS-J-1121	63.70	300.00	120.00	5.77	0.08	0.04
HS-P-893	HS-J-1120	HS-J-1123	30.18	300.00	120.00	3.88	0.05	0.02
HS-P-879	HS-J-1121	HS-J-1109	70.41	300.00	120.00	3.87	0.05	0.02
HS-P-872	HS-J-1122	HS-J-1107	23.77	300.00	120.00	8.75	0.12	0.08
HS-P-871	HS-J-1102	HS-J-1122	86.87	300.00	120.00	8.75	0.12	0.08
HS-P-877	HS-J-1107	HS-J-1108	109.42	300.00	120.00	8.75	0.12	0.08
HS-P-870	J-1103	HS-J-1102	83.52	300.00	120.00	8.75	0.12	0.08
HS-P-886	HS-J-1121	HS-J-1120	80.47	300.00	120.00	-2.40	0.03	0.01
HS-P-889	HS-J-1116	HS-J-1124	53.34	300.00	120.00	-6.28	0.09	0.04
HS-P-883	HS-J-1118	J-1129	84.12	300.00	120.00	-6.28	0.09	0.04
HS-P-890	HS-J-1124	HS-J-1117	179.22	300.00	120.00	-6.28	0.09	0.04
HS-P-891	HS-J-1117	HS-J-1119	128.32	300.00	120.00	-6.28	0.09	0.04
HS-P-888	HS-J-1115	HS-J-1116	130.15	300.00	120.00	-6.28	0.09	0.04
HS-P-892	HS-J-1119	HS-J-1118	54.86	300.00	120.00	-6.28	0.09	0.04
HS-P-887	HS-J-1120	HS-J-1115	28.96	300.00	120.00	-6.28	0.09	0.04



Junctions Tables
Full Buildout - 70% TWL

221-10826-00

2021 ADD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	273.43	372
J-1103	235.24	0.00	273.43	374
HS-J-1123	234.98	1.29	273.43	376
HS-J-1115	234.91	0.00	273.43	377
HS-J-1124	234.85	0.00	273.43	378
HS-J-1117	234.54	0.00	273.43	381
HS-J-1120	234.43	0.00	273.43	382
HS-J-1102	234.23	0.00	273.43	384
HS-J-1121	234.00	1.43	273.43	386
HS-J-1108	233.73	0.00	273.43	388
HS-J-1110	233.44	0.99	273.43	391
HS-J-1107	233.41	0.00	273.43	392
HS-J-1109	232.98	1.29	273.43	396
HS-J-1122	232.97	0.00	273.43	396
HS-J-1119	232.92	0.00	273.44	397
HS-J-1118	232.70	0.00	273.44	399
J-1129	232.36	0.00	273.44	402
HS-J-1106	232.22	0.00	273.43	403
HS-J-1103	229.11	0.00	273.43	434
HS-J-1104	229.04	0.00	273.43	434
HS-J-1105	229.00	0.00	273.43	435
Sum of Demand:		5.01	Min	372
			Max	435



Junctions Tables
Full Buildout - 70% TWL

221-10826-00

2021 MDD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	271.93	358
J-1103	235.24	0.00	271.93	359
HS-J-1123	234.98	2.46	271.93	362
HS-J-1115	234.91	0.00	271.93	362
HS-J-1124	234.85	0.00	271.94	363
HS-J-1117	234.54	0.00	271.94	366
HS-J-1120	234.43	0.00	271.93	367
HS-J-1102	234.23	0.00	271.93	369
HS-J-1121	234.00	2.72	271.93	371
HS-J-1108	233.73	0.00	271.93	374
HS-J-1110	233.44	1.89	271.93	377
HS-J-1107	233.41	0.00	271.93	377
HS-J-1109	232.98	2.45	271.93	381
HS-J-1122	232.97	0.00	271.93	381
HS-J-1119	232.92	0.00	271.95	382
HS-J-1118	232.70	0.00	271.95	384
J-1129	232.36	0.00	271.95	387
HS-J-1106	232.22	0.00	271.93	389
HS-J-1103	229.11	0.00	271.93	419
HS-J-1104	229.04	0.00	271.93	420
HS-J-1105	229.00	0.00	271.93	420
Sum of Demand:		9.52	Min	358
			Max	420



Junctions Tables
Full Buildout - 70% TWL

221-10826-00

2021 PHD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	267.27	312
J-1103	235.24	0.00	267.29	314
HS-J-1123	234.98	3.88	267.26	316
HS-J-1115	234.91	0.00	267.26	317
HS-J-1124	234.85	0.00	267.27	317
HS-J-1117	234.54	0.00	267.28	320
HS-J-1120	234.43	0.00	267.26	321
HS-J-1102	234.23	0.00	267.28	323
HS-J-1121	234.00	4.30	267.26	326
HS-J-1108	233.73	0.00	267.26	328
HS-J-1110	233.44	2.98	267.26	331
HS-J-1107	233.41	0.00	267.27	331
HS-J-1109	232.98	3.87	267.26	335
HS-J-1122	232.97	0.00	267.27	336
HS-J-1119	232.92	0.00	267.29	336
HS-J-1118	232.70	0.00	267.29	339
J-1129	232.36	0.00	267.29	342
HS-J-1106	232.22	0.00	267.27	343
HS-J-1103	229.11	0.00	267.27	373
HS-J-1104	229.04	0.00	267.27	374
HS-J-1105	229.00	0.00	267.27	375
Sum of Demand:		15.03	Min	312
			Max	375

2021 ADD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
HS-P-894	HS-J-1108	HS-J-1110	7.92	300.00	120.00	0.99	0.01	0.00
HS-P-873	HS-J-1103	HS-J-1104	11.28	300.00	120.00	0.00	0.00	0.00
HS-P-876	HS-J-1106	HS-J-1107	78.33	300.00	120.00	0.00	0.00	0.00
HS-P-874	HS-J-1103	HS-J-1105	88.09	300.00	120.00	0.00	0.00	0.00
HS-P-875	HS-J-1105	HS-J-1106	178.92	300.00	120.00	0.00	0.00	0.00
P-879	HS-J-1118	H-187	6.10	150.00	100.00	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150.00	100.00	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150.00	100.00	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150.00	100.00	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150.00	100.00	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150.00	100.00	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150.00	100.00	0.00	0.00	0.00
HS-P-878	HS-J-1108	HS-J-1121	63.70	300.00	120.00	0.42	0.01	0.00
HS-P-893	HS-J-1120	HS-J-1123	30.18	300.00	120.00	1.29	0.02	0.00
HS-P-879	HS-J-1121	HS-J-1109	70.41	300.00	120.00	1.29	0.02	0.00
HS-P-872	HS-J-1122	HS-J-1107	23.77	300.00	120.00	1.41	0.02	0.00
HS-P-871	HS-J-1102	HS-J-1122	86.87	300.00	120.00	1.41	0.02	0.00
HS-P-877	HS-J-1107	HS-J-1108	109.42	300.00	120.00	1.41	0.02	0.00
HS-P-870	J-1103	HS-J-1102	83.52	300.00	120.00	1.41	0.02	0.00
HS-P-886	HS-J-1121	HS-J-1120	80.47	300.00	120.00	-2.31	0.03	0.01
HS-P-889	HS-J-1116	HS-J-1124	53.34	300.00	120.00	-3.60	0.05	0.02
HS-P-883	HS-J-1118	J-1129	84.12	300.00	120.00	-3.60	0.05	0.02
HS-P-890	HS-J-1124	HS-J-1117	179.22	300.00	120.00	-3.60	0.05	0.02
HS-P-891	HS-J-1117	HS-J-1119	128.32	300.00	120.00	-3.60	0.05	0.02
HS-P-888	HS-J-1115	HS-J-1116	130.15	300.00	120.00	-3.60	0.05	0.02
HS-P-892	HS-J-1119	HS-J-1118	54.86	300.00	120.00	-3.60	0.05	0.02
HS-P-887	HS-J-1120	HS-J-1115	28.96	300.00	120.00	-3.60	0.05	0.02

2021 MDD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
HS-P-894	HS-J-1108	HS-J-1110	7.92	300.00	120.00	1.89	0.03	0.00
HS-P-873	HS-J-1103	HS-J-1104	11.28	300.00	120.00	0.00	0.00	0.00
HS-P-876	HS-J-1106	HS-J-1107	78.33	300.00	120.00	0.00	0.00	0.00
HS-P-874	HS-J-1103	HS-J-1105	88.09	300.00	120.00	0.00	0.00	0.00
HS-P-875	HS-J-1105	HS-J-1106	178.92	300.00	120.00	0.00	0.00	0.00
P-879	HS-J-1118	H-187	6.10	150.00	100.00	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150.00	100.00	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150.00	100.00	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150.00	100.00	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150.00	100.00	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150.00	100.00	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150.00	100.00	0.00	0.00	0.00
HS-P-878	HS-J-1108	HS-J-1121	63.70	300.00	120.00	1.88	0.03	0.00
HS-P-893	HS-J-1120	HS-J-1123	30.18	300.00	120.00	2.46	0.03	0.01
HS-P-879	HS-J-1121	HS-J-1109	70.41	300.00	120.00	2.45	0.03	0.01
HS-P-872	HS-J-1122	HS-J-1107	23.77	300.00	120.00	3.77	0.05	0.02
HS-P-871	HS-J-1102	HS-J-1122	86.87	300.00	120.00	3.77	0.05	0.02
HS-P-877	HS-J-1107	HS-J-1108	109.42	300.00	120.00	3.77	0.05	0.02
HS-P-870	J-1103	HS-J-1102	83.52	300.00	120.00	3.77	0.05	0.02
HS-P-886	HS-J-1121	HS-J-1120	80.47	300.00	120.00	-3.29	0.05	0.01
HS-P-889	HS-J-1116	HS-J-1124	53.34	300.00	120.00	-5.75	0.08	0.04
HS-P-883	HS-J-1118	J-1129	84.12	300.00	120.00	-5.75	0.08	0.04
HS-P-890	HS-J-1124	HS-J-1117	179.22	300.00	120.00	-5.75	0.08	0.04
HS-P-891	HS-J-1117	HS-J-1119	128.32	300.00	120.00	-5.75	0.08	0.04
HS-P-888	HS-J-1115	HS-J-1116	130.15	300.00	120.00	-5.75	0.08	0.04
HS-P-892	HS-J-1119	HS-J-1118	54.86	300.00	120.00	-5.75	0.08	0.04
HS-P-887	HS-J-1120	HS-J-1115	28.96	300.00	120.00	-5.75	0.08	0.04

2021 PHD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
HS-P-894	HS-J-1108	HS-J-1110	7.92	300.00	120.00	2.98	0.04	0.01
HS-P-873	HS-J-1103	HS-J-1104	11.28	300.00	120.00	0.00	0.00	0.00
HS-P-876	HS-J-1106	HS-J-1107	78.33	300.00	120.00	0.00	0.00	0.00
HS-P-874	HS-J-1103	HS-J-1105	88.09	300.00	120.00	0.00	0.00	0.00
HS-P-875	HS-J-1105	HS-J-1106	178.92	300.00	120.00	0.00	0.00	0.00
P-879	HS-J-1118	H-187	6.10	150.00	100.00	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150.00	100.00	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150.00	100.00	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150.00	100.00	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150.00	100.00	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150.00	100.00	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150.00	100.00	0.00	0.00	0.00
HS-P-878	HS-J-1108	HS-J-1121	63.70	300.00	120.00	5.64	0.08	0.04
HS-P-893	HS-J-1120	HS-J-1123	30.18	300.00	120.00	3.88	0.05	0.02
HS-P-879	HS-J-1121	HS-J-1109	70.41	300.00	120.00	3.87	0.05	0.02
HS-P-872	HS-J-1122	HS-J-1107	23.77	300.00	120.00	8.62	0.12	0.08
HS-P-871	HS-J-1102	HS-J-1122	86.87	300.00	120.00	8.62	0.12	0.08
HS-P-877	HS-J-1107	HS-J-1108	109.42	300.00	120.00	8.62	0.12	0.08
HS-P-870	J-1103	HS-J-1102	83.52	300.00	120.00	8.62	0.12	0.08
HS-P-886	HS-J-1121	HS-J-1120	80.47	300.00	120.00	-2.53	0.04	0.01
HS-P-889	HS-J-1116	HS-J-1124	53.34	300.00	120.00	-6.41	0.09	0.05
HS-P-883	HS-J-1118	J-1129	84.12	300.00	120.00	-6.41	0.09	0.05
HS-P-890	HS-J-1124	HS-J-1117	179.22	300.00	120.00	-6.41	0.09	0.05
HS-P-891	HS-J-1117	HS-J-1119	128.32	300.00	120.00	-6.41	0.09	0.05
HS-P-888	HS-J-1115	HS-J-1116	130.15	300.00	120.00	-6.41	0.09	0.05
HS-P-892	HS-J-1119	HS-J-1118	54.86	300.00	120.00	-6.41	0.09	0.05
HS-P-887	HS-J-1120	HS-J-1115	28.96	300.00	120.00	-6.41	0.09	0.05



Junctions Tables
Full Buildout - 70% TWL

221-10826-00

2031 ADD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	272.33	361
J-1103	235.24	0.00	272.33	363
HS-J-1123	234.98	1.29	272.33	366
HS-J-1115	234.91	0.00	272.33	366
HS-J-1124	234.85	0.00	272.33	367
HS-J-1117	234.54	0.00	272.34	370
HS-J-1120	234.43	0.00	272.33	371
HS-J-1102	234.23	0.00	272.33	373
HS-J-1121	234.00	1.43	272.33	375
HS-J-1108	233.73	0.00	272.33	378
HS-J-1110	233.44	0.99	272.33	381
HS-J-1107	233.41	0.00	272.33	381
HS-J-1109	232.98	1.29	272.33	385
HS-J-1122	232.97	0.00	272.33	385
HS-J-1119	232.92	0.00	272.34	386
HS-J-1118	232.70	0.00	272.34	388
J-1129	232.36	0.00	272.34	391
HS-J-1106	232.22	0.00	272.33	393
HS-J-1103	229.11	0.00	272.33	423
HS-J-1104	229.04	0.00	272.33	424
HS-J-1105	229.00	0.00	272.33	424
Sum of Demand:		5.01	Min	361
			Max	424



Junctions Tables
Full Buildout - 70% TWL

221-10826-00

2031 MDD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	270.63	345
J-1103	235.24	0.00	270.63	346
HS-J-1123	234.98	2.45	270.62	349
HS-J-1115	234.91	0.00	270.63	350
HS-J-1124	234.85	0.00	270.63	350
HS-J-1117	234.54	0.00	270.64	353
HS-J-1120	234.43	0.00	270.62	354
HS-J-1102	234.23	0.00	270.63	356
HS-J-1121	234.00	1.89	270.62	358
HS-J-1108	233.73	0.00	270.62	361
HS-J-1110	233.44	2.46	270.62	364
HS-J-1107	233.41	0.00	270.63	364
HS-J-1109	232.98	2.72	270.62	368
HS-J-1122	232.97	0.00	270.63	369
HS-J-1119	232.92	0.00	270.64	369
HS-J-1118	232.70	0.00	270.65	371
J-1129	232.36	0.00	270.65	375
HS-J-1106	232.22	0.00	270.63	376
HS-J-1103	229.11	0.00	270.63	406
HS-J-1104	229.04	0.00	270.63	407
HS-J-1105	229.00	0.00	270.63	407
Sum of Demand:		9.52	Min	345
			Max	407



Junctions Tables
Full Buildout - 70% TWL

221-10826-00

2031 PHD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	265.37	293
J-1103	235.24	0.00	265.39	295
HS-J-1123	234.98	4.00	265.36	297
HS-J-1115	234.91	0.00	265.36	298
HS-J-1124	234.85	0.00	265.37	299
HS-J-1117	234.54	0.00	265.38	302
HS-J-1120	234.43	0.00	265.36	303
HS-J-1102	234.23	0.00	265.38	305
HS-J-1121	234.00	4.00	265.36	307
HS-J-1108	233.73	0.00	265.36	310
HS-J-1110	233.44	3.00	265.36	312
HS-J-1107	233.41	0.00	265.37	313
HS-J-1109	232.98	4.00	265.36	317
HS-J-1122	232.97	0.00	265.37	317
HS-J-1119	232.92	0.00	265.38	318
HS-J-1118	232.70	0.00	265.38	320
J-1129	232.36	0.00	265.39	323
HS-J-1106	232.22	0.00	265.37	324
HS-J-1103	229.11	0.00	265.37	355
HS-J-1104	229.04	0.00	265.37	356
HS-J-1105	229.00	0.00	265.37	356
Sum of Demand:		15.00	Min	293
			Max	356



Pipe Tables
Full Buildout - 70% TWL

221-10826-00

2031 ADD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
HS-P-894	HS-J-1108	HS-J-1110	7.92	300.00	120.00	0.99	0.01	0.00
HS-P-873	HS-J-1103	HS-J-1104	11.28	300.00	120.00	0.00	0.00	0.00
HS-P-876	HS-J-1106	HS-J-1107	78.33	300.00	120.00	0.00	0.00	0.00
HS-P-874	HS-J-1103	HS-J-1105	88.09	300.00	120.00	0.00	0.00	0.00
HS-P-875	HS-J-1105	HS-J-1106	178.92	300.00	120.00	0.00	0.00	0.00
P-879	HS-J-1118	H-187	6.10	150.00	100.00	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150.00	100.00	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150.00	100.00	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150.00	100.00	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150.00	100.00	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150.00	100.00	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150.00	100.00	0.00	0.00	0.00
HS-P-878	HS-J-1108	HS-J-1121	63.70	300.00	120.00	0.33	0.00	0.00
HS-P-893	HS-J-1120	HS-J-1123	30.18	300.00	120.00	1.29	0.02	0.00
HS-P-879	HS-J-1121	HS-J-1109	70.41	300.00	120.00	1.29	0.02	0.00
HS-P-872	HS-J-1122	HS-J-1107	23.77	300.00	120.00	1.32	0.02	0.00
HS-P-871	HS-J-1102	HS-J-1122	86.87	300.00	120.00	1.32	0.02	0.00
HS-P-877	HS-J-1107	HS-J-1108	109.42	300.00	120.00	1.32	0.02	0.00
HS-P-870	J-1103	HS-J-1102	83.52	300.00	120.00	1.32	0.02	0.00
HS-P-886	HS-J-1121	HS-J-1120	80.47	300.00	120.00	-2.40	0.03	0.01
HS-P-889	HS-J-1116	HS-J-1124	53.34	300.00	120.00	-3.69	0.05	0.02
HS-P-883	HS-J-1118	J-1129	84.12	300.00	120.00	-3.69	0.05	0.02
HS-P-890	HS-J-1124	HS-J-1117	179.22	300.00	120.00	-3.69	0.05	0.02
HS-P-891	HS-J-1117	HS-J-1119	128.32	300.00	120.00	-3.69	0.05	0.02
HS-P-888	HS-J-1115	HS-J-1116	130.15	300.00	120.00	-3.69	0.05	0.02
HS-P-892	HS-J-1119	HS-J-1118	54.86	300.00	120.00	-3.69	0.05	0.02
HS-P-887	HS-J-1120	HS-J-1115	28.96	300.00	120.00	-3.69	0.05	0.02



Pipe Tables
Full Buildout - 70% TWL

221-10826-00

2031 MDD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
HS-P-894	HS-J-1108	HS-J-1110	7.92	300.00	120.00	2.46	0.03	0.01
HS-P-873	HS-J-1103	HS-J-1104	11.28	300.00	120.00	0.00	0.00	0.00
HS-P-876	HS-J-1106	HS-J-1107	78.33	300.00	120.00	0.00	0.00	0.00
HS-P-874	HS-J-1103	HS-J-1105	88.09	300.00	120.00	0.00	0.00	0.00
HS-P-875	HS-J-1105	HS-J-1106	178.92	300.00	120.00	0.00	0.00	0.00
P-879	HS-J-1118	H-187	6.10	150.00	100.00	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150.00	100.00	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150.00	100.00	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150.00	100.00	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150.00	100.00	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150.00	100.00	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150.00	100.00	0.00	0.00	0.00
HS-P-878	HS-J-1108	HS-J-1121	63.70	300.00	120.00	1.32	0.02	0.00
HS-P-893	HS-J-1120	HS-J-1123	30.18	300.00	120.00	2.45	0.03	0.01
HS-P-879	HS-J-1121	HS-J-1109	70.41	300.00	120.00	2.72	0.04	0.01
HS-P-872	HS-J-1122	HS-J-1107	23.77	300.00	120.00	3.78	0.05	0.02
HS-P-871	HS-J-1102	HS-J-1122	86.87	300.00	120.00	3.78	0.05	0.02
HS-P-877	HS-J-1107	HS-J-1108	109.42	300.00	120.00	3.78	0.05	0.02
HS-P-870	J-1103	HS-J-1102	83.52	300.00	120.00	3.78	0.05	0.02
HS-P-886	HS-J-1121	HS-J-1120	80.47	300.00	120.00	-3.29	0.05	0.01
HS-P-889	HS-J-1116	HS-J-1124	53.34	300.00	120.00	-5.74	0.08	0.04
HS-P-883	HS-J-1118	J-1129	84.12	300.00	120.00	-5.74	0.08	0.04
HS-P-890	HS-J-1124	HS-J-1117	179.22	300.00	120.00	-5.74	0.08	0.04
HS-P-891	HS-J-1117	HS-J-1119	128.32	300.00	120.00	-5.74	0.08	0.04
HS-P-888	HS-J-1115	HS-J-1116	130.15	300.00	120.00	-5.74	0.08	0.04
HS-P-892	HS-J-1119	HS-J-1118	54.86	300.00	120.00	-5.74	0.08	0.04
HS-P-887	HS-J-1120	HS-J-1115	28.96	300.00	120.00	-5.74	0.08	0.04



Pipe Tables
Full Buildout - 70% TWL

221-10826-00

2031 PHD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
HS-P-894	HS-J-1108	HS-J-1110	7.92	300.00	120.00	2.98	0.04	0.01
HS-P-873	HS-J-1103	HS-J-1104	11.28	300.00	120.00	0.00	0.00	0.00
HS-P-876	HS-J-1106	HS-J-1107	78.33	300.00	120.00	0.00	0.00	0.00
HS-P-874	HS-J-1103	HS-J-1105	88.09	300.00	120.00	0.00	0.00	0.00
HS-P-875	HS-J-1105	HS-J-1106	178.92	300.00	120.00	0.00	0.00	0.00
P-879	HS-J-1118	H-187	6.10	150.00	100.00	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150.00	100.00	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150.00	100.00	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150.00	100.00	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150.00	100.00	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150.00	100.00	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150.00	100.00	0.00	0.00	0.00
HS-P-878	HS-J-1108	HS-J-1121	63.70	300.00	120.00	5.72	0.08	0.04
HS-P-893	HS-J-1120	HS-J-1123	30.18	300.00	120.00	3.88	0.05	0.02
HS-P-879	HS-J-1121	HS-J-1109	70.41	300.00	120.00	3.87	0.05	0.02
HS-P-872	HS-J-1122	HS-J-1107	23.77	300.00	120.00	8.70	0.12	0.08
HS-P-871	HS-J-1102	HS-J-1122	86.87	300.00	120.00	8.70	0.12	0.08
HS-P-877	HS-J-1107	HS-J-1108	109.42	300.00	120.00	8.70	0.12	0.08
HS-P-870	J-1103	HS-J-1102	83.52	300.00	120.00	8.70	0.12	0.08
HS-P-886	HS-J-1121	HS-J-1120	80.47	300.00	120.00	-2.45	0.03	0.01
HS-P-889	HS-J-1116	HS-J-1124	53.34	300.00	120.00	-6.33	0.09	0.04
HS-P-883	HS-J-1118	J-1129	84.12	300.00	120.00	-6.33	0.09	0.04
HS-P-890	HS-J-1124	HS-J-1117	179.22	300.00	120.00	-6.33	0.09	0.04
HS-P-891	HS-J-1117	HS-J-1119	128.32	300.00	120.00	-6.33	0.09	0.04
HS-P-888	HS-J-1115	HS-J-1116	130.15	300.00	120.00	-6.33	0.09	0.05
HS-P-892	HS-J-1119	HS-J-1118	54.86	300.00	120.00	-6.33	0.09	0.05
HS-P-887	HS-J-1120	HS-J-1115	28.96	300.00	120.00	-6.33	0.09	0.04



Junctions Tables
Full Buildout (Option 2) - 50% TWL

221-10826-00

2021 ADD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	273.47	357
J-1103	235.24	0.00	273.43	358
HS-J-1123	234.98	1.29	273.47	361
HS-J-1115	234.91	0.00	273.47	362
HS-J-1124	234.85	0.00	273.47	362
HS-J-1117	234.54	0.00	273.47	365
HS-J-1120	234.43	0.00	273.47	366
HS-J-1121	234.00	1.43	273.47	371
HS-J-1108	233.73	0.00	273.47	373
HS-J-1110	233.44	0.99	273.47	376
HS-J-1107	233.41	0.00	273.48	376
HS-J-1109	232.98	1.29	273.47	381
HS-J-1119	232.92	0.00	273.47	381
HS-J-1118	232.70	0.00	273.47	383
J-1129	232.36	0.00	273.47	387
HS-J-1106	232.22	0.00	273.48	388
HS-J-1103	229.11	0.00	273.49	419
HS-J-1104	229.04	0.00	273.49	419
HS-J-1105	229.00	0.00	273.49	420
J-1108	228.18	0.00	273.50	428
J-1109	227.00	0.00	273.51	439
Sum of Demand:		5.01	Min	357
			Max	439



Junctions Tables
Full Buildout (Option 2) - 50% TWL

221-10826-00

2021 MDD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	270.50	344
J-1103	235.24	0.00	270.46	345
HS-J-1123	234.98	2.46	270.50	348
HS-J-1115	234.91	0.00	270.50	348
HS-J-1124	234.85	0.00	270.50	349
HS-J-1117	234.54	0.00	270.50	352
HS-J-1120	234.43	0.00	270.50	353
HS-J-1121	234.00	2.72	270.50	357
HS-J-1108	233.73	0.00	270.50	360
HS-J-1110	233.44	1.89	270.50	363
HS-J-1107	233.41	0.00	270.51	363
HS-J-1109	232.98	2.45	270.50	367
HS-J-1119	232.92	0.00	270.50	368
HS-J-1118	232.70	0.00	270.50	370
J-1129	232.36	0.00	270.50	373
HS-J-1106	232.22	0.00	270.51	375
HS-J-1103	229.11	0.00	270.53	405
HS-J-1104	229.04	0.00	270.53	406
HS-J-1105	229.00	0.00	270.52	406
J-1108	228.18	0.00	270.54	415
J-1109	227.00	0.00	270.55	426
Sum of Demand:		9.52	Min	344
			Max	426



Junctions Tables
Full Buildout (Option 2) - 50% TWL

221-10826-00

2021 PHD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	265.67	296
J-1103	235.24	0.00	265.65	298
HS-J-1123	234.98	3.88	265.67	300
HS-J-1115	234.91	0.00	265.67	301
HS-J-1124	234.85	0.00	265.67	302
HS-J-1117	234.54	0.00	265.68	305
HS-J-1120	234.43	0.00	265.67	306
HS-J-1121	234.00	4.30	265.67	310
HS-J-1108	233.73	0.00	265.68	313
HS-J-1110	233.44	2.98	265.68	316
HS-J-1107	233.41	0.00	265.70	316
HS-J-1109	232.98	3.87	265.67	320
HS-J-1119	232.92	0.00	265.68	321
HS-J-1118	232.70	0.00	265.68	323
J-1129	232.36	0.00	265.68	326
HS-J-1106	232.22	0.00	265.71	328
HS-J-1103	229.11	0.00	265.75	359
HS-J-1104	229.04	0.00	265.75	359
HS-J-1105	229.00	0.00	265.74	360
J-1108	228.18	0.00	265.77	368
J-1109	227.00	0.00	265.80	380
Sum of Demand:		15.03	Min	296
			Max	380



Pipe Tables
Full Buildout (Option 2) - 50% TWL

221-10826-00

2021 ADD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
HS-P-894	HS-J-1108	HS-J-1110	7.92	300	120	0.99	0.01	0.00
P-879	HS-J-1118	H-187	6.10	150	100	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150	100	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150	100	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150	100	0.00	0.00	0.00
P-889	J-1108	H-195	6.10	150	100	0.00	0.00	0.00
P-890	J-1109	H-196	6.10	150	100	0.00	0.00	0.00
HS-P-883	HS-J-1118	J-1129	84.12	300	120	1.16	0.02	0.00
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	1.16	0.02	0.00
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	1.16	0.02	0.00
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	1.16	0.02	0.00
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	1.16	0.02	0.00
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	1.16	0.02	0.00
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	1.16	0.02	0.00
HS-P-879	HS-J-1121	HS-J-1109	70.41	300	120	1.29	0.02	0.00
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	1.29	0.02	0.00
HS-P-886	HS-J-1121	HS-J-1120	80.47	300	120	2.45	0.03	0.01
HS-P-878	HS-J-1108	HS-J-1121	63.70	300	120	5.17	0.07	0.03
P-886(1)	HS-J-1104	J-1108	124.66	300	120	-6.17	0.09	0.04
P-886(2)(2)	J-1109	J-1105	87.48	300	120	-6.17	0.09	0.04
HS-P-876	HS-J-1106	HS-J-1107	78.33	300	120	6.17	0.09	0.04
HS-P-875	HS-J-1105	HS-J-1106	178.92	300	120	6.17	0.09	0.04
HS-P-877	HS-J-1107	HS-J-1108	109.42	300	120	6.17	0.09	0.04
P-886(2)(1)	J-1108	J-1109	170.99	300	120	-6.17	0.09	0.04
HS-P-874	HS-J-1103	HS-J-1105	88.09	300	120	6.17	0.09	0.04
HS-P-873	HS-J-1103	HS-J-1104	11.28	300	120	-6.17	0.09	0.04



Pipe Tables
Full Buildout (Option 2) - 50% TWL

221-10826-00

2021 MDD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
HS-P-894	HS-J-1108	HS-J-1110	7.92	300	120	1.89	0.03	0.00
P-879	HS-J-1118	H-187	6.10	150	100	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150	100	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150	100	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150	100	0.00	0.00	0.00
P-889	J-1108	H-195	6.10	150	100	0.00	0.00	0.00
P-890	J-1109	H-196	6.10	150	100	0.00	0.00	0.00
HS-P-883	HS-J-1118	J-1129	84.12	300	120	-2.16	0.03	0.01
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	-2.16	0.03	0.01
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	-2.16	0.03	0.01
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	-2.16	0.03	0.01
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	-2.16	0.03	0.01
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	-2.16	0.03	0.01
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	-2.16	0.03	0.01
HS-P-879	HS-J-1121	HS-J-1109	70.41	300	120	2.45	0.03	0.01
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	2.46	0.03	0.01
HS-P-886	HS-J-1121	HS-J-1120	80.47	300	120	0.30	0.00	0.00
HS-P-878	HS-J-1108	HS-J-1121	63.70	300	120	5.48	0.08	0.03
P-886(1)	HS-J-1104	J-1108	124.66	300	120	-7.37	0.10	0.06
P-886(2)(2)	J-1109	J-1105	87.48	300	120	-7.37	0.10	0.06
HS-P-876	HS-J-1106	HS-J-1107	78.33	300	120	7.37	0.10	0.06
HS-P-875	HS-J-1105	HS-J-1106	178.92	300	120	7.37	0.10	0.06
HS-P-877	HS-J-1107	HS-J-1108	109.42	300	120	7.37	0.10	0.06
P-886(2)(1)	J-1108	J-1109	170.99	300	120	-7.37	0.10	0.06
HS-P-874	HS-J-1103	HS-J-1105	88.09	300	120	7.37	0.10	0.06
HS-P-873	HS-J-1103	HS-J-1104	11.28	300	120	-7.37	0.10	0.06



Pipe Tables
Full Buildout (Option 2) - 50% TWL

221-10826-00

2021 PHD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
HS-P-894	HS-J-1108	HS-J-1110	7.92	300	120	2.98	0.04	0.01
P-879	HS-J-1118	H-187	6.10	150	100	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150	100	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150	100	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150	100	0.00	0.00	0.00
P-889	J-1108	H-195	6.10	150	100	0.00	0.00	0.00
P-890	J-1109	H-196	6.10	150	100	0.00	0.00	0.00
HS-P-883	HS-J-1118	J-1129	84.12	300	120	-2.48	0.04	0.01
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	-2.48	0.04	0.01
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	-2.48	0.04	0.01
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	-2.48	0.04	0.01
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	-2.48	0.04	0.01
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	-2.48	0.04	0.01
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	-2.48	0.04	0.01
HS-P-879	HS-J-1121	HS-J-1109	70.41	300	120	3.87	0.05	0.02
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	3.88	0.05	0.02
HS-P-886	HS-J-1121	HS-J-1120	80.47	300	120	1.40	0.02	0.00
HS-P-878	HS-J-1108	HS-J-1121	63.70	300	120	9.57	0.14	0.10
P-886(1)	HS-J-1104	J-1108	124.66	300	120	-12.55	0.18	0.16
P-886(2)(2)	J-1109	J-1105	87.48	300	120	-12.55	0.18	0.16
HS-P-876	HS-J-1106	HS-J-1107	78.33	300	120	12.55	0.18	0.16
HS-P-875	HS-J-1105	HS-J-1106	178.92	300	120	12.55	0.18	0.16
HS-P-877	HS-J-1107	HS-J-1108	109.42	300	120	12.55	0.18	0.16
P-886(2)(1)	J-1108	J-1109	170.99	300	120	-12.55	0.18	0.16
HS-P-874	HS-J-1103	HS-J-1105	88.09	300	120	12.55	0.18	0.16
HS-P-873	HS-J-1103	HS-J-1104	11.28	300	120	-12.55	0.18	0.16



Junctions Tables
Full Buildout (Option 2) - 50% TWL

221-10826-00

2031 ADD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	270.91	348
J-1103	235.24	0.00	270.87	349
HS-J-1123	234.98	1.29	270.91	352
HS-J-1115	234.91	0.00	270.91	352
HS-J-1124	234.85	0.00	270.91	353
HS-J-1117	234.54	0.00	270.91	356
HS-J-1120	234.43	0.00	270.91	357
HS-J-1121	234.00	1.43	270.91	361
HS-J-1108	233.73	0.00	270.92	364
HS-J-1110	233.44	0.99	270.92	367
HS-J-1107	233.41	0.00	270.92	367
HS-J-1109	232.98	1.29	270.91	371
HS-J-1119	232.92	0.00	270.91	372
HS-J-1118	232.70	0.00	270.91	374
J-1129	232.36	0.00	270.91	377
HS-J-1106	232.22	0.00	270.93	379
HS-J-1103	229.11	0.00	270.94	409
HS-J-1104	229.04	0.00	270.94	410
HS-J-1105	229.00	0.00	270.93	410
J-1108	228.18	0.00	270.95	419
J-1109	227.00	0.00	270.95	430

Sum of Demand:

5.01

Min

348

Max

430



Junctions Tables
Full Buildout (Option 2) - 50% TWL

221-10826-00

2031 MDD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	269.40	333
J-1103	235.24	0.00	269.36	334
HS-J-1123	234.98	2.45	269.40	337
HS-J-1115	234.91	0.00	269.40	338
HS-J-1124	234.85	0.00	269.40	338
HS-J-1117	234.54	0.00	269.40	341
HS-J-1120	234.43	0.00	269.40	342
HS-J-1121	234.00	1.89	269.40	346
HS-J-1108	233.73	0.00	269.41	349
HS-J-1110	233.44	2.46	269.41	352
HS-J-1107	233.41	0.00	269.41	352
HS-J-1109	232.98	2.72	269.40	356
HS-J-1119	232.92	0.00	269.40	357
HS-J-1118	232.70	0.00	269.40	359
J-1129	232.36	0.00	269.40	363
HS-J-1106	232.22	0.00	269.42	364
HS-J-1103	229.11	0.00	269.44	395
HS-J-1104	229.04	0.00	269.44	395
HS-J-1105	229.00	0.00	269.43	396
J-1108	228.18	0.00	269.45	404
J-1109	227.00	0.00	269.46	416

Sum of Demand:

9.52

Min

333

Max

416



Junctions Tables
Full Buildout (Option 2) - 50% TWL

221-10826-00

2031 PHD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	264.00	280
J-1103	235.24	0.00	263.96	281
HS-J-1123	234.98	3.88	263.99	284
HS-J-1115	234.91	0.00	263.99	285
HS-J-1124	234.85	0.00	264.00	285
HS-J-1117	234.54	0.00	264.00	288
HS-J-1120	234.43	0.00	263.99	289
HS-J-1121	234.00	4.30	264.00	294
HS-J-1108	233.73	0.00	264.00	296
HS-J-1110	233.44	2.98	264.00	299
HS-J-1107	233.41	0.00	264.02	300
HS-J-1109	232.98	3.87	263.99	304
HS-J-1119	232.92	0.00	264.00	304
HS-J-1118	232.70	0.00	264.00	306
J-1129	232.36	0.00	264.00	310
HS-J-1106	232.22	0.00	264.04	311
HS-J-1103	229.11	0.00	264.09	342
HS-J-1104	229.04	0.00	264.09	343
HS-J-1105	229.00	0.00	264.07	343
J-1108	228.18	0.00	264.11	352
J-1109	227.00	0.00	264.14	363
Sum of Demand:		15.03	Min	280
			Max	363



Pipe Tables
Full Buildout (Option 2) - 50% TWL

221-10826-00

2031 ADD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
HS-P-894	HS-J-1108	HS-J-1110	7.92	300	120	0.99	0.01	0.00
P-879	HS-J-1118	H-187	6.10	150	100	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150	100	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150	100	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150	100	0.00	0.00	0.00
P-889	J-1108	H-195	6.10	150	100	0.00	0.00	0.00
P-890	J-1109	H-196	6.10	150	100	0.00	0.00	0.00
HS-P-883	HS-J-1118	J-1129	84.12	300	120	1.67	0.02	0.00
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	1.67	0.02	0.00
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	1.67	0.02	0.00
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	1.67	0.02	0.00
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	1.67	0.02	0.00
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	1.67	0.02	0.00
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	1.67	0.02	0.00
HS-P-879	HS-J-1121	HS-J-1109	70.41	300	120	1.29	0.02	0.00
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	1.29	0.02	0.00
HS-P-886	HS-J-1121	HS-J-1120	80.47	300	120	2.97	0.04	0.01
HS-P-878	HS-J-1108	HS-J-1121	63.70	300	120	5.69	0.08	0.04
P-886(1)	HS-J-1104	J-1108	124.66	300	120	-6.68	0.09	0.05
P-886(2)(2)	J-1109	J-1105	87.48	300	120	-6.68	0.09	0.05
HS-P-876	HS-J-1106	HS-J-1107	78.33	300	120	6.68	0.09	0.05
HS-P-875	HS-J-1105	HS-J-1106	178.92	300	120	6.68	0.09	0.05
HS-P-877	HS-J-1107	HS-J-1108	109.42	300	120	6.68	0.09	0.05
P-886(2)(1)	J-1108	J-1109	170.99	300	120	-6.68	0.09	0.05
HS-P-874	HS-J-1103	HS-J-1105	88.09	300	120	6.68	0.09	0.05
HS-P-873	HS-J-1103	HS-J-1104	11.28	300	120	-6.68	0.09	0.05



Pipe Tables
Full Buildout (Option 2) - 50% TWL

221-10826-00

2031 MDD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
HS-P-894	HS-J-1108	HS-J-1110	7.92	300	120	2.459	0.0	0.0
P-879	HS-J-1118	H-187	6.1	150	100	0	0.0	0.0
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150	100	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150	100	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150	100	0.00	0.00	0.00
P-889	J-1108	H-195	6.10	150	100	0.00	0.00	0.00
P-890	J-1109	H-196	6.10	150	100	0.00	0.00	0.00
HS-P-883	HS-J-1118	J-1129	84.12	300	120	-1.29	0.02	0.00
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	-1.29	0.02	0.00
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	-1.29	0.02	0.00
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	-1.29	0.02	0.00
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	-1.29	0.02	0.00
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	-1.29	0.02	0.00
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	-1.29	0.02	0.00
HS-P-879	HS-J-1121	HS-J-1109	70.41	300	120	2.72	0.04	0.01
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	2.45	0.03	0.01
HS-P-886	HS-J-1121	HS-J-1120	80.47	300	120	1.16	0.02	0.00
HS-P-878	HS-J-1108	HS-J-1121	63.70	300	120	5.77	0.08	0.04
P-886(1)	HS-J-1104	J-1108	124.66	300	120	-8.23	0.12	0.07
P-886(2)(2)	J-1109	J-1105	87.48	300	120	-8.23	0.12	0.07
HS-P-876	HS-J-1106	HS-J-1107	78.33	300	120	8.23	0.12	0.07
HS-P-875	HS-J-1105	HS-J-1106	178.92	300	120	8.23	0.12	0.07
HS-P-877	HS-J-1107	HS-J-1108	109.42	300	120	8.23	0.12	0.07
P-886(2)(1)	J-1108	J-1109	170.99	300	120	-8.23	0.12	0.07
HS-P-874	HS-J-1103	HS-J-1105	88.09	300	120	8.23	0.12	0.07
HS-P-873	HS-J-1103	HS-J-1104	11.28	300	120	-8.23	0.12	0.07



Pipe Tables
Full Buildout (Option 2) - 50% TWL

221-10826-00

2031 PHD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
HS-P-894	HS-J-1108	HS-J-1110	7.92	300	120	2.98	0.04	0.01
P-879	HS-J-1118	H-187	6.10	150	100	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150	100	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150	100	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150	100	0.00	0.00	0.00
P-889	J-1108	H-195	6.10	150	100	0.00	0.00	0.00
P-890	J-1109	H-196	6.10	150	100	0.00	0.00	0.00
HS-P-883	HS-J-1118	J-1129	84.12	300	120	-1.55	0.02	0.00
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	-1.55	0.02	0.00
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	-1.55	0.02	0.00
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	-1.55	0.02	0.00
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	-1.55	0.02	0.00
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	-1.55	0.02	0.00
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	-1.55	0.02	0.00
HS-P-879	HS-J-1121	HS-J-1109	70.41	300	120	3.87	0.05	0.02
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	3.88	0.05	0.02
HS-P-886	HS-J-1121	HS-J-1120	80.47	300	120	2.34	0.03	0.01
HS-P-878	HS-J-1108	HS-J-1121	63.70	300	120	10.51	0.15	0.11
P-886(1)	HS-J-1104	J-1108	124.66	300	120	-13.48	0.19	0.18
P-886(2)(2)	J-1109	J-1105	87.48	300	120	-13.48	0.19	0.18
HS-P-876	HS-J-1106	HS-J-1107	78.33	300	120	13.48	0.19	0.18
HS-P-875	HS-J-1105	HS-J-1106	178.92	300	120	13.48	0.19	0.18
HS-P-877	HS-J-1107	HS-J-1108	109.42	300	120	13.48	0.19	0.18
P-886(2)(1)	J-1108	J-1109	170.99	300	120	-13.48	0.19	0.18
HS-P-874	HS-J-1103	HS-J-1105	88.09	300	120	13.48	0.19	0.18
HS-P-873	HS-J-1103	HS-J-1104	11.28	300	120	-13.48	0.19	0.18



Junctions Tables
Full Buildout (Option 2) - 70% TWL

221-10826-00

2021 ADD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	273.47	373
J-1103	235.24	0.00	273.43	374
HS-J-1123	234.98	1.29	273.47	377
HS-J-1115	234.91	0.00	273.47	377
HS-J-1124	234.85	0.00	273.47	378
HS-J-1117	234.54	0.00	273.47	381
HS-J-1120	234.43	0.00	273.47	382
HS-J-1121	234.00	1.43	273.47	386
HS-J-1108	233.73	0.00	273.47	389
HS-J-1110	233.44	0.99	273.47	392
HS-J-1107	233.41	0.00	273.48	392
HS-J-1109	232.98	1.29	273.47	396
HS-J-1119	232.92	0.00	273.47	397
HS-J-1118	232.70	0.00	273.47	399
J-1129	232.36	0.00	273.47	402
HS-J-1106	232.22	0.00	273.48	404
HS-J-1103	229.11	0.00	273.49	434
HS-J-1104	229.04	0.00	273.49	435
HS-J-1105	229.00	0.00	273.49	435
J-1108	228.18	0.00	273.50	444
J-1109	227.00	0.00	273.51	455
Sum of Demand:		5.01	Min	373
			Max	455



Junctions Tables
Full Buildout (Option 2) - 70% TWL

221-10826-00

2021 MDD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	271.99	358
J-1103	235.24	0.00	271.95	359
HS-J-1123	234.98	2.46	271.99	362
HS-J-1115	234.91	0.00	271.99	363
HS-J-1124	234.85	0.00	271.99	363
HS-J-1117	234.54	0.00	271.99	366
HS-J-1120	234.43	0.00	271.99	368
HS-J-1121	234.00	2.72	271.99	372
HS-J-1108	233.73	0.00	271.99	374
HS-J-1110	233.44	1.89	271.99	377
HS-J-1107	233.41	0.00	271.99	378
HS-J-1109	232.98	2.45	271.98	382
HS-J-1119	232.92	0.00	271.99	382
HS-J-1118	232.70	0.00	271.99	385
J-1129	232.36	0.00	271.99	388
HS-J-1106	232.22	0.00	272.00	389
HS-J-1103	229.11	0.00	272.01	420
HS-J-1104	229.04	0.00	272.01	421
HS-J-1105	229.00	0.00	272.01	421
J-1108	228.18	0.00	272.02	429
J-1109	227.00	0.00	272.03	441
Sum of Demand:		9.52	Min	358
			Max	441



Junctions Tables
Full Buildout (Option 2) - 70% TWL

221-10826-00

2021 PHD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	266.65	306
J-1103	235.24	0.00	266.62	307
HS-J-1123	234.98	3.88	266.65	310
HS-J-1115	234.91	0.00	266.65	311
HS-J-1124	234.85	0.00	266.65	311
HS-J-1117	234.54	0.00	266.65	314
HS-J-1120	234.43	0.00	266.65	315
HS-J-1121	234.00	4.30	266.65	320
HS-J-1108	233.73	0.00	266.66	322
HS-J-1110	233.44	2.98	266.66	325
HS-J-1107	233.41	0.00	266.67	326
HS-J-1109	232.98	3.87	266.65	330
HS-J-1119	232.92	0.00	266.66	330
HS-J-1118	232.70	0.00	266.66	332
J-1129	232.36	0.00	266.66	336
HS-J-1106	232.22	0.00	266.68	337
HS-J-1103	229.11	0.00	266.73	368
HS-J-1104	229.04	0.00	266.73	369
HS-J-1105	229.00	0.00	266.71	369
J-1108	228.18	0.00	266.75	377
J-1109	227.00	0.00	266.77	389
Sum of Demand:		15.03	Min	306
			Max	389



Pipe Tables
Full Buildout (Option 2) - 70% TWL

221-10826-00

2021 ADD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
P-879	HS-J-1118	H-187	6.10	150	100	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150	100	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150	100	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150	100	0.00	0.00	0.00
P-889	J-1108	H-195	6.10	150	100	0.00	0.00	0.00
P-890	J-1109	H-196	6.10	150	100	0.00	0.00	0.00
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	1.16	0.02	0.00
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	1.16	0.02	0.00
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	1.16	0.02	0.00
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	1.16	0.02	0.00
HS-P-883	HS-J-1118	J-1129	84.12	300	120	1.16	0.02	0.00
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	1.16	0.02	0.00
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	1.16	0.02	0.00
HS-P-894	HS-J-1108	HS-J-1110	7.92	300	120	0.99	0.01	0.00
HS-P-879	HS-J-1121	HS-J-1109	70.41	300	120	1.29	0.02	0.00
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	1.29	0.02	0.00
HS-P-886	HS-J-1121	HS-J-1120	80.47	300	120	2.45	0.03	0.01
HS-P-878	HS-J-1108	HS-J-1121	63.70	300	120	5.17	0.07	0.03
HS-P-874	HS-J-1103	HS-J-1105	88.09	300	120	6.17	0.09	0.04
P-886(2)(2)	J-1109	J-1105	87.48	300	120	-6.17	0.09	0.04
HS-P-876	HS-J-1106	HS-J-1107	78.33	300	120	6.17	0.09	0.04
P-886(1)	HS-J-1104	J-1108	124.66	300	120	-6.17	0.09	0.04
HS-P-875	HS-J-1105	HS-J-1106	178.92	300	120	6.17	0.09	0.04
HS-P-877	HS-J-1107	HS-J-1108	109.42	300	120	6.17	0.09	0.04
P-886(2)(1)	J-1108	J-1109	170.99	300	120	-6.17	0.09	0.04
HS-P-873	HS-J-1103	HS-J-1104	11.28	300	120	-6.17	0.09	0.04



Pipe Tables
Full Buildout (Option 2) - 70% TWL

221-10826-00

2021 MDD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
P-879	HS-J-1118	H-187	6.10	150	100	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150	100	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150	100	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150	100	0.00	0.00	0.00
P-889	J-1108	H-195	6.10	150	100	0.00	0.00	0.00
P-890	J-1109	H-196	6.10	150	100	0.00	0.00	0.00
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	-2.24	0.03	0.01
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	-2.24	0.03	0.01
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	-2.24	0.03	0.01
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	-2.24	0.03	0.01
HS-P-883	HS-J-1118	J-1129	84.12	300	120	-2.24	0.03	0.01
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	-2.24	0.03	0.01
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	-2.24	0.03	0.01
HS-P-894	HS-J-1108	HS-J-1110	7.92	300	120	1.89	0.03	0.01
HS-P-879	HS-J-1121	HS-J-1109	70.41	300	120	2.45	0.03	0.01
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	2.46	0.03	0.01
HS-P-886	HS-J-1121	HS-J-1120	80.47	300	120	0.22	0.00	0.00
HS-P-878	HS-J-1108	HS-J-1121	63.70	300	120	5.39	0.08	0.03
HS-P-874	HS-J-1103	HS-J-1105	88.09	300	120	7.28	0.10	0.06
P-886(2)(2)	J-1109	J-1105	87.48	300	120	-7.28	0.10	0.06
HS-P-876	HS-J-1106	HS-J-1107	78.33	300	120	7.28	0.10	0.06
P-886(1)	HS-J-1104	J-1108	124.66	300	120	-7.28	0.10	0.06
HS-P-875	HS-J-1105	HS-J-1106	178.92	300	120	7.28	0.10	0.06
HS-P-877	HS-J-1107	HS-J-1108	109.42	300	120	7.28	0.10	0.06
P-886(2)(1)	J-1108	J-1109	170.99	300	120	-7.28	0.10	0.06
HS-P-873	HS-J-1103	HS-J-1104	11.28	300	120	-7.28	0.10	0.06



Pipe Tables
Full Buildout (Option 2) - 70% TWL

221-10826-00

2021 PHD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
P-895	J-1106	H-182	6.10	150	100	0.00	0.00	0.00
P-898	J-1125	H-185	6.10	150	100	0.00	0.00	0.00
P-894	J-1105	H-181	6.10	150	100	0.00	0.00	0.00
P-873	J-1103	J-1104	11.28	300	120	0.00	0.00	0.00
P-874	J-1103	J-1105	88.09	300	120	0.00	0.00	0.00
P-876	J-1106	J-1107	78.33	300	120	0.00	0.00	0.00
P-875	J-1105	J-1106	178.92	300	120	0.00	0.00	0.00
P-893	J-1103	H-180	6.10	150	100	0.00	0.00	0.00
P-901	J-1136	H-188	6.10	150	100	0.00	0.00	0.00
P-896	J-1122	H-183	6.10	150	100	0.00	0.00	0.00
P-897	J-1124	H-184	6.10	150	100	0.00	0.00	0.00
P-878	J-1108	J-1133	151.79	300	120	0.03	0.00	0.00
P-877	J-1107	J-1108	20.12	300	120	0.03	0.00	0.00
P-872	J-1134	J-1107	23.77	300	120	0.03	0.00	0.00
P-900	J-1134	J-1110	10.36	300	120	2.98	0.04	0.01
P-870	J-1130	J-1102	72.54	300	120	3.01	0.04	0.01
P-871	J-1102	J-1134	224.64	300	120	3.01	0.04	0.01
P-879	J-1133	J-1109	70.41	300	120	3.87	0.05	0.02
P-899	J-1132	J-1135	30.18	300	120	3.88	0.05	0.02
P-886	J-1133	J-1132	80.47	300	120	-8.14	0.12	0.07
P-887	J-1132	J-1122	28.96	300	120	-12.03	0.17	0.15
P-888	J-1122	J-1123	130.15	300	120	-12.03	0.17	0.15
P-889	J-1123	J-1136	53.34	300	120	-12.03	0.17	0.15
P-890	J-1136	J-1124	179.22	300	120	-12.03	0.17	0.15
P-883	J-1125	J-1129	84.12	300	120	-12.03	0.17	0.15
P-891	J-1124	J-1131	128.32	300	120	-12.03	0.17	0.15
P-892	J-1131	J-1125	54.86	300	120	-12.03	0.17	0.15



Junctions Tables
Full Buildout (Option 2) - 70% TWL

221-10826-00

2031 ADD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	272.38	362
J-1103	235.24	0.00	272.34	363
HS-J-1123	234.98	1.29	272.38	366
HS-J-1115	234.91	0.00	272.38	367
HS-J-1124	234.85	0.00	272.38	367
HS-J-1117	234.54	0.00	272.38	370
HS-J-1120	234.43	0.00	272.38	371
HS-J-1121	234.00	1.43	272.38	376
HS-J-1108	233.73	0.00	272.39	378
HS-J-1110	233.44	0.99	272.39	381
HS-J-1107	233.41	0.00	272.39	382
HS-J-1109	232.98	1.29	272.38	386
HS-J-1119	232.92	0.00	272.38	386
HS-J-1118	232.70	0.00	272.38	388
J-1129	232.36	0.00	272.38	392
HS-J-1106	232.22	0.00	272.40	393
HS-J-1103	229.11	0.00	272.41	424
HS-J-1104	229.04	0.00	272.41	424
HS-J-1105	229.00	0.00	272.40	425
J-1108	228.18	0.00	272.42	433
J-1109	227.00	0.00	272.42	445
Sum of Demand:		5.01	Min	362
			Max	445



Junctions Tables
Full Buildout (Option 2) - 70% TWL

221-10826-00

2031 MDD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	270.89	347
J-1103	235.24	0.00	270.85	348
HS-J-1123	234.98	2.45	270.89	351
HS-J-1115	234.91	0.00	270.89	352
HS-J-1124	234.85	0.00	270.89	353
HS-J-1117	234.54	0.00	270.89	356
HS-J-1120	234.43	0.00	270.89	357
HS-J-1121	234.00	1.89	270.89	361
HS-J-1108	233.73	0.00	270.89	364
HS-J-1110	233.44	2.46	270.89	367
HS-J-1107	233.41	0.00	270.90	367
HS-J-1109	232.98	2.72	270.89	371
HS-J-1119	232.92	0.00	270.89	372
HS-J-1118	232.70	0.00	270.89	374
J-1129	232.36	0.00	270.89	377
HS-J-1106	232.22	0.00	270.90	379
HS-J-1103	229.11	0.00	270.92	409
HS-J-1104	229.04	0.00	270.92	410
HS-J-1105	229.00	0.00	270.92	410
J-1108	228.18	0.00	270.93	418
J-1109	227.00	0.00	270.94	430
Sum of Demand:		9.52	Min	347
			Max	430



Junctions Tables
Full Buildout (Option 2) - 70% TWL

221-10826-00

2031 PHD Junction Results				
Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)
HS-J-1116	235.40	0.00	265.47	294
J-1103	235.24	0.00	265.44	296
HS-J-1123	234.98	3.88	265.47	298
HS-J-1115	234.91	0.00	265.47	299
HS-J-1124	234.85	0.00	265.47	300
HS-J-1117	234.54	0.00	265.47	303
HS-J-1120	234.43	0.00	265.47	304
HS-J-1121	234.00	4.30	265.47	308
HS-J-1108	233.73	0.00	265.48	311
HS-J-1110	233.44	2.98	265.48	314
HS-J-1107	233.41	0.00	265.50	314
HS-J-1109	232.98	3.87	265.47	318
HS-J-1119	232.92	0.00	265.47	319
HS-J-1118	232.70	0.00	265.47	321
J-1129	232.36	0.00	265.47	324
HS-J-1106	232.22	0.00	265.51	326
HS-J-1103	229.11	0.00	265.56	357
HS-J-1104	229.04	0.00	265.56	357
HS-J-1105	229.00	0.00	265.54	358
J-1108	228.18	0.00	265.58	366
J-1109	227.00	0.00	265.62	378
Sum of Demand:		15.03	Min	294
			Max	378



Pipe Tables
Full Buildout (Option 2) - 70% TWL

221-10826-00

2031 ADD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
P-879	HS-J-1118	H-187	6.1	150	100	0	0.0	0.0
P-880	HS-J-1117	H-188	6.1	150	100	0	0.0	0.0
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150	100	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150	100	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150	100	0.00	0.00	0.00
P-889	J-1108	H-195	6.10	150	100	0.00	0.00	0.00
P-890	J-1109	H-196	6.10	150	100	0.00	0.00	0.00
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	1.58	0.02	0.00
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	1.58	0.02	0.00
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	1.58	0.02	0.00
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	1.58	0.02	0.00
HS-P-883	HS-J-1118	J-1129	84.12	300	120	1.58	0.02	0.00
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	1.58	0.02	0.00
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	1.58	0.02	0.00
HS-P-894	HS-J-1108	HS-J-1110	7.92	300	120	0.99	0.01	0.00
HS-P-879	HS-J-1121	HS-J-1109	70.41	300	120	1.29	0.02	0.00
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	1.29	0.02	0.00
HS-P-886	HS-J-1121	HS-J-1120	80.47	300	120	2.87	0.04	0.01
HS-P-878	HS-J-1108	HS-J-1121	63.70	300	120	5.59	0.08	0.04
HS-P-874	HS-J-1103	HS-J-1105	88.09	300	120	6.59	0.09	0.05
P-886(2)(2)	J-1109	J-1105	87.48	300	120	-6.59	0.09	0.05
HS-P-876	HS-J-1106	HS-J-1107	78.33	300	120	6.59	0.09	0.05
P-886(1)	HS-J-1104	J-1108	124.66	300	120	-6.59	0.09	0.05
HS-P-875	HS-J-1105	HS-J-1106	178.92	300	120	6.59	0.09	0.05
HS-P-877	HS-J-1107	HS-J-1108	109.42	300	120	6.59	0.09	0.05
P-886(2)(1)	J-1108	J-1109	170.99	300	120	-6.59	0.09	0.05
HS-P-873	HS-J-1103	HS-J-1104	11.28	300	120	-6.59	0.09	0.05



Pipe Tables
Full Buildout (Option 2) - 70% TWL

221-10826-00

2031 MDD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
P-879	HS-J-1118	H-187	6.10	150	100	0.00	0.00	0.00
P-880	HS-J-1117	H-188	6.10	150	100	0.00	0.00	0.00
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150	100	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150	100	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150	100	0.00	0.00	0.00
P-889	J-1108	H-195	6.10	150	100	0.00	0.00	0.00
P-890	J-1109	H-196	6.10	150	100	0.00	0.00	0.00
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	-1.38	0.02	0.00
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	-1.38	0.02	0.00
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	-1.38	0.02	0.00
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	-1.38	0.02	0.00
HS-P-883	HS-J-1118	J-1129	84.12	300	120	-1.38	0.02	0.00
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	-1.38	0.02	0.00
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	-1.38	0.02	0.00
HS-P-894	HS-J-1108	HS-J-1110	7.92	300	120	2.46	0.03	0.01
HS-P-879	HS-J-1121	HS-J-1109	70.41	300	120	2.72	0.04	0.01
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	2.45	0.03	0.01
HS-P-886	HS-J-1121	HS-J-1120	80.47	300	120	1.07	0.02	0.00
HS-P-878	HS-J-1108	HS-J-1121	63.70	300	120	5.68	0.08	0.04
HS-P-874	HS-J-1103	HS-J-1105	88.09	300	120	8.14	0.12	0.07
P-886(2)(2)	J-1109	J-1105	87.48	300	120	-8.14	0.12	0.07
HS-P-876	HS-J-1106	HS-J-1107	78.33	300	120	8.14	0.12	0.07
P-886(1)	HS-J-1104	J-1108	124.66	300	120	-8.14	0.12	0.07
HS-P-875	HS-J-1105	HS-J-1106	178.92	300	120	8.14	0.12	0.07
HS-P-877	HS-J-1107	HS-J-1108	109.42	300	120	8.14	0.12	0.07
P-886(2)(1)	J-1108	J-1109	170.99	300	120	-8.14	0.12	0.07
HS-P-873	HS-J-1103	HS-J-1104	11.28	300	120	-8.14	0.12	0.07



Pipe Tables
Full Buildout (Option 2) - 70% TWL


221-10826-00

2031 PHD Pipe Results								
Label	Start Node	Stop Node	Length (m)	Diameter (mm)	Hazen-Williams C	Flow (L/s)	Velocity (m/s)	Headloss Gradient (m/km)
P-879	HS-J-1118	H-187	6.1	150	100	0.00	0.0	0.0
P-880	HS-J-1117	H-188	6.1	150	100	0.00	0.0	0.0
P-881	HS-J-1124	H-189	6.10	150	100	0.00	0.00	0.00
P-882	HS-J-1115	H-191	6.10	150	100	0.00	0.00	0.00
P-883	HS-J-1106	H-190	6.10	150	100	0.00	0.00	0.00
P-884	HS-J-1105	H-192	6.10	150	100	0.00	0.00	0.00
P-885	HS-J-1103	H-193	6.10	150	100	0.00	0.00	0.00
P-889	J-1108	H-195	6.10	150	100	0.00	0.00	0.00
P-890	J-1109	H-196	6.10	150	100	0.00	0.00	0.00
HS-P-889	HS-J-1116	HS-J-1124	53.34	300	120	-1.61	0.02	0.00
HS-P-891	HS-J-1117	HS-J-1119	128.32	300	120	-1.61	0.02	0.00
HS-P-887	HS-J-1120	HS-J-1115	28.96	300	120	-1.61	0.02	0.00
HS-P-890	HS-J-1124	HS-J-1117	179.22	300	120	-1.61	0.02	0.00
HS-P-883	HS-J-1118	J-1129	84.12	300	120	-1.61	0.02	0.00
HS-P-888	HS-J-1115	HS-J-1116	130.15	300	120	-1.61	0.02	0.00
HS-P-892	HS-J-1119	HS-J-1118	54.86	300	120	-1.61	0.02	0.00
HS-P-894	HS-J-1108	HS-J-1110	7.92	300	120	2.98	0.04	0.01
HS-P-879	HS-J-1121	HS-J-1109	70.41	300	120	3.87	0.05	0.02
HS-P-893	HS-J-1120	HS-J-1123	30.18	300	120	3.88	0.05	0.02
HS-P-886	HS-J-1121	HS-J-1120	80.47	300	120	2.27	0.03	0.01
HS-P-878	HS-J-1108	HS-J-1121	63.70	300	120	10.44	0.15	0.11
HS-P-874	HS-J-1103	HS-J-1105	88.09	300	120	13.42	0.19	0.18
P-886(2)(2)	J-1109	J-1105	87.48	300	120	-13.42	0.19	0.18
HS-P-876	HS-J-1106	HS-J-1107	78.33	300	120	13.42	0.19	0.18
P-886(1)	HS-J-1104	J-1108	124.66	300	120	-13.42	0.19	0.18
HS-P-875	HS-J-1105	HS-J-1106	178.92	300	120	13.42	0.19	0.18
HS-P-877	HS-J-1107	HS-J-1108	109.42	300	120	13.42	0.19	0.18
P-886(2)(1)	J-1108	J-1109	170.99	300	120	-13.42	0.19	0.18
HS-P-873	HS-J-1103	HS-J-1104	11.28	300	120	-13.42	0.19	0.18

APPENDIX

C

FIRE FLOW REPORT



2021 MDD + FF - 70% TWL											
Label	Elevation (m)	Fire Flow (Needed) (L/s)	Fire Flow (Available) (L/s)	Satisfies Fire Flow Constraints?	Hydraulic Grade (m)	Pressure (Residual Lower Limit) (kPa)	Pressure (Zone Lower Limit) (kPa)	Pressure (Calculated Residual) (kPa)	Pressure (Calculated Zone Lower Limit) (kPa)	Junction w/ Minimum Pressure (System)	Junction w/ Minimum Pressure (Zone)
GJ10H006	234.42	250	241	N/A	272	140	140	140	195	HD38T004	SE06V108
GJ10H007	234.73	250	239	N/A	272	140	140	140	195	HD38T004	SE06V108
GJ10H008	233.63	250	245	N/A	272	140	140	140	195	HD38T004	SE06V108
GJ10H009	232.91	250	249	N/A	272	140	140	140	195	HD38T004	SE06V108
GJ10H010	232.43	250	253	N/A	272	140	140	140	194	HD38T004	SE06V108
GJ10H011	232.63	250	222	N/A	272	140	140	140	196	HD38T004	SE06V108
GJ10H012	233.64	250	233	N/A	272	140	140	140	195	HD38T004	SE06V108
GJ10H014	232.48	250	268	N/A	272	140	140	140	194	HD38T004	SE06V108
H-187	232.70	250	233	FALSE	272	140	140	140	195	HD38T004	SE06V108
H-188	234.54	250	193	FALSE	272	140	140	140	193	HS-J-1116	SE06V108
H-189	234.85	250	171	FALSE	272	140	140	140	184	HS-J-1116	SE06V108
H-191	234.91	250	156	FALSE	272	140	140	140	181	HS-J-1123	SE06V108
		Minimum	156								
		Maximum	268								



Fire Flow Tables
Phase 1

221-10826-00

2021 MDD + FF - 99% TWL

Label	Elevation (m)	Fire Flow (Needed) (L/s)	Fire Flow (Available) (L/s)	Satisfies Fire Flow Constraints?	Hydraulic Grade (m)	Pressure (Residual Lower Limit) (kPa)	Pressure (Zone Lower Limit) (kPa)	Pressure (Calculated Residual) (kPa)	Pressure (Calculated Zone Lower Limit) (kPa)	Junction w/ Minimum Pressure (System)	Junction w/ Minimum Pressure (Zone)
GJ10H006	234.42	250	254	N/A	274	140	140	140	213	HD38T004	SE06V108
GJ10H007	234.73	250	252	N/A	274	140	140	140	213	HD38T004	SE06V108
GJ10H008	233.63	250	257	N/A	274	140	140	140	213	HD38T004	SE06V108
GJ10H009	232.91	250	262	N/A	274	140	140	140	213	HD38T004	SE06V108
GJ10H010	232.43	250	265	N/A	274	140	140	140	213	HD38T004	SE06V108
GJ10H011	232.63	250	233	N/A	274	140	140	140	214	HD38T004	SE06V108
GJ10H012	233.64	250	245	N/A	274	140	140	140	214	HD38T004	SE06V108
GJ10H014	232.48	250	281	N/A	274	140	140	140	212	HD38T004	SE06V108
H-187	232.70	250	244	FALSE	274	140	140	140	209	HS-J-1116	SE06V108
H-188	234.54	250	203	FALSE	274	140	140	140	199	HS-J-1116	SE06V108
H-189	234.85	250	180	FALSE	274	140	140	140	189	HS-J-1116	SE06V108
H-191	234.91	250	164	FALSE	274	140	140	140	185	HS-J-1123	SE06V108

Minimum	164
Maximum	281



Fire Flow Tables
Phase 1

221-10826-00

2031 MDD + FF - 50%

Label	Elevation (m)	Fire Flow (Needed) (L/s)	Fire Flow (Available) (L/s)	Satisfies Fire Flow Constraints?	Hydraulic Grade (m)	Pressure (Residual Lower Limit) (kPa)	Pressure (Zone Lower Limit) (kPa)	Pressure (Calculated Residual) (kPa)	Pressure (Calculated Zone Lower Limit) (kPa)	Junction w/ Minimum Pressure (System)	Junction w/ Minimum Pressure (Zone)
GJ10H006	234.42	250	220	N/A	269	140	140	140	174	HD38T004	SE06V108
GJ10H007	234.73	250	217	N/A	269	140	140	140	174	HD38T004	SE06V108
GJ10H008	233.63	250	224	N/A	269	140	140	140	174	HD38T004	SE06V108
GJ10H009	232.91	250	228	N/A	269	140	140	140	174	HD38T004	SE06V108
GJ10H010	232.43	250	232	N/A	269	140	140	140	174	HD38T004	SE06V108
GJ10H011	232.63	250	204	N/A	269	140	140	140	175	HD38T004	SE06V108
GJ10H012	233.64	250	214	N/A	269	140	140	140	175	HD38T004	SE06V108
GJ10H014	232.48	250	245	N/A	269	140	140	140	173	HD38T004	SE06V108
H-187	232.70	250	214	FALSE	269	140	140	140	174	HD38T004	SE06V108
H-188	234.54	250	176	FALSE	269	140	140	140	176	HD38T004	SE06V108
H-189	234.85	250	157	FALSE	269	140	140	140	177	HS-J-1116	SE06V108
H-191	234.91	250	143	FALSE	269	140	140	140	175	HS-J-1123	SE06V108

Minimum	143
Maximum	245

2031 MDD + FF - 70%

Label	Elevation (m)	Fire Flow (Needed) (L/s)	Fire Flow (Available) (L/s)	Satisfies Fire Flow Constraints?	Hydraulic Grade (m)	Pressure (Residual Lower Limit) (kPa)	Pressure (Zone Lower Limit) (kPa)	Pressure (Calculated Residual) (kPa)	Pressure (Calculated Zone Lower Limit) (kPa)	Junction w/ Minimum Pressure (System)	Junction w/ Minimum Pressure (Zone)
GJ10H006	234.42	250	229	N/A	271	140	140	140	187	HD38T004	SE06V108
GJ10H007	234.73	250	227	N/A	271	140	140	140	187	HD38T004	SE06V108
GJ10H008	233.63	250	233	N/A	271	140	140	140	187	HD38T004	SE06V108
GJ10H009	232.91	250	238	N/A	271	140	140	140	187	HD38T004	SE06V108
GJ10H010	232.43	250	241	N/A	271	140	140	140	187	HD38T004	SE06V108
GJ10H011	232.63	250	213	N/A	271	140	140	140	188	HD38T004	SE06V108
GJ10H012	233.64	250	223	N/A	271	140	140	140	188	HD38T004	SE06V108
GJ10H014	232.48	250	255	N/A	271	140	140	140	186	HD38T004	SE06V108
H-187	232.70	250	223	FALSE	271	140	140	140	188	HD38T004	SE06V108
H-188	234.54	250	184	FALSE	271	140	140	140	188	HS-J-1116	SE06V108
H-189	234.85	250	164	FALSE	271	140	140	140	180	HS-J-1116	SE06V108
H-191	234.91	250	149	FALSE	271	140	140	140	178	HS-J-1123	SE06V108

Minimum	149
Maximum	255




Fire Flow Tables
Phase 1

221-10826-00


2031 MDD + FF - 99%

Label	Elevation (m)	Fire Flow (Needed) (L/s)	Fire Flow (Available) (L/s)	Satisfies Fire Flow Constraints?	Hydraulic Grade (m)	Pressure (Residual Lower Limit) (kPa)	Pressure (Zone Lower Limit) (kPa)	Pressure (Calculated Residual) (kPa)	Pressure (Calculated Zone Lower Limit) (kPa)	Junction w/ Minimum Pressure (System)	Junction w/ Minimum Pressure (Zone)
GJ10H006	234.42	250	242	N/A	273	140	140	140	205	HD38T004	SE06V108
GJ10H007	234.73	250	240	N/A	273	140	140	140	205	HD38T004	SE06V108
GJ10H008	233.63	250	246	N/A	273	140	140	140	205	HD38T004	SE06V108
GJ10H009	232.91	250	250	N/A	273	140	140	140	205	HD38T004	SE06V108
GJ10H010	232.43	250	254	N/A	273	140	140	140	204	HD38T004	SE06V108
GJ10H011	232.63	250	223	N/A	273	140	140	140	206	HD38T004	SE06V108
GJ10H012	233.64	250	235	N/A	273	140	140	140	205	HD38T004	SE06V108
GJ10H014	232.48	250	269	N/A	273	140	140	140	204	HD38T004	SE06V108
H-187	232.70	250	234	FALSE	273	140	140	140	202	HS-J-1116	SE06V108
H-188	234.54	250	194	FALSE	273	140	140	140	194	HS-J-1116	SE06V108
H-189	234.85	250	173	FALSE	273	140	140	140	185	HS-J-1116	SE06V108
H-191	234.91	250	158	FALSE	273	140	140	140	182	HS-J-1123	SE06V108

Minimum	158
Maximum	269



2021 MDD + FF - 70% TWL											
Label	Elevation (m)	Fire Flow (Needed) (L/s)	Fire Flow (Available) (L/s)	Satisfies Fire Flow Constraints?	Hydraulic Grade (m)	Pressure (Residual Lower Limit) (kPa)	Pressure (Zone Lower Limit) (kPa)	Pressure (Calculated Residual) (kPa)	Pressure (Calculated Zone Lower Limit) (kPa)	Junction w/ Minimum Pressure (System)	Junction w/ Minimum Pressure (Zone)
GJ10H006	234.42	250	239	N/A	272	140	140	140	195	HD38T004	SE06V108
GJ10H007	234.73	250	236	N/A	272	140	140	140	195	HD38T004	SE06V108
GJ10H008	233.63	250	242	N/A	272	140	140	140	195	HD38T004	SE06V108
GJ10H009	232.91	250	246	N/A	272	140	140	140	194	HD38T004	SE06V108
GJ10H010	232.43	250	249	N/A	272	140	140	140	194	HD38T004	SE06V108
GJ10H011	232.63	250	220	N/A	272	140	140	140	196	HD38T004	SE06V108
GJ10H012	233.64	250	231	N/A	272	140	140	140	195	HD38T004	SE06V108
GJ10H014	232.48	250	266	N/A	272	140	140	140	193	HD38T004	SE06V108
H-187	232.70	250	239	FALSE	272	140	140	140	195	HD38T004	SE06V108
H-188	234.54	250	215	FALSE	272	140	140	140	196	HD38T004	SE06V108
H-189	234.85	250	208	FALSE	272	140	140	140	196	HD38T004	SE06V108
H-190	232.22	250	217	FALSE	272	140	140	140	196	HD38T004	SE06V108
H-191	234.91	250	207	FALSE	272	140	140	140	196	HD38T004	SE06V108
H-192	229.00	250	207	FALSE	272	140	140	140	196	HD38T004	SE06V108
H-193	229.11	250	196	FALSE	272	140	140	140	197	HD38T004	SE06V108
		Minimum	196								
		Maximum	266								



		Maximum	275	2031 MDD + FF - 50% TWL							
Label	Elevation (m)	Fire Flow (Needed) (L/s)	Fire Flow (Available) (L/s)	Satisfies Fire Flow Constraints?	Hydraulic Grade (m)	Pressure (Residual Lower Limit) (kPa)	Pressure (Zone Lower Limit) (kPa)	Pressure (Calculated Residual) (kPa)	Pressure (Calculated Zone Lower Limit) (kPa)	Junction w/ Minimum Pressure (System)	Junction w/ Minimum Pressure (Zone)
GJ10H006	234.42	250	217	N/A	269	140	140	140	173	HD38T004	SE06V108
GJ10H007	234.73	250	214	N/A	269	140	140	140	173	HD38T004	SE06V108
GJ10H008	233.63	250	220	N/A	269	140	140	140	173	HD38T004	SE06V108
GJ10H009	232.91	250	224	N/A	269	140	140	140	172	HD38T004	SE06V108
GJ10H010	232.43	250	228	N/A	269	140	140	140	172	HD38T004	SE06V108
GJ10H011	232.63	250	201	N/A	269	140	140	140	174	HD38T004	SE06V108
GJ10H012	233.64	250	211	N/A	269	140	140	140	173	HD38T004	SE06V108
GJ10H014	232.48	250	243	N/A	269	140	140	140	172	HD38T004	SE06V108
H-187	232.70	250	219	FALSE	269	140	140	140	173	HD38T004	SE06V108
H-188	234.54	250	196	FALSE	269	140	140	140	174	HD38T004	SE06V108
H-189	234.85	250	189	FALSE	269	140	140	140	174	HD38T004	SE06V108
H-190	232.22	250	200	FALSE	269	140	140	140	174	HD38T004	SE06V108
H-191	234.91	250	188	FALSE	269	140	140	140	174	HD38T004	SE06V108
H-192	229.00	250	193	FALSE	269	140	140	140	174	HD38T004	SE06V108
H-193	229.11	250	183	FALSE	269	140	140	140	175	HD38T004	SE06V108
		Minimum	183								
		Maximum	243								



Fire Flow Tables
Full Buildout - Option 2

221-10826-00

2021 MDD + FF - 50% TWL											
Label	Elevation (m)	Fire Flow (Needed) (L/s)	Fire Flow (Available) (L/s)	Satisfies Fire Flow Constraints?	Hydraulic Grade (m)	Pressure (Residual Lower Limit) (kPa)	Pressure (Zone Lower Limit) (kPa)	Pressure (Calculated Residual) (kPa)	Pressure (Calculated Zone Lower Limit) (kPa)	Junction w/ Minimum Pressure (System)	Junction w/ Minimum Pressure (Zone)
GJ10H006	234.42	250	228	N/A	270	140	140	140	182	HD38T004	SE06V108
GJ10H007	234.73	250	226	N/A	270	140	140	140	182	HD38T004	SE06V108
GJ10H008	233.63	250	233	N/A	270	140	140	140	181	HD38T004	SE06V108
GJ10H009	232.91	250	238	N/A	270	140	140	140	181	HD38T004	SE06V108
GJ10H010	232.43	250	242	N/A	270	140	140	140	181	HD38T004	SE06V108
GJ10H011	232.63	250	214	N/A	270	140	140	140	182	HD38T004	SE06V108
GJ10H012	233.64	250	225	N/A	270	140	140	140	182	HD38T004	SE06V108
GJ10H014	232.48	250	259	N/A	271	140	140	140	180	HD38T004	SE06V108
H-187	232.70	250	233	FALSE	271	140	140	140	181	HD38T004	SE06V108
H-188	234.54	250	207	FALSE	271	140	140	140	183	HD38T004	SE06V108
H-189	234.85	250	197	FALSE	271	140	140	140	183	HD38T004	SE06V108
H-190	232.22	250	206	FALSE	271	140	140	140	183	HD38T004	SE06V108
H-191	234.91	250	192	FALSE	270	140	140	140	183	HD38T004	SE06V108
H-192	229.00	250	228	FALSE	271	140	140	140	182	HD38T004	SE06V108
H-193	229.11	250	231	FALSE	271	140	140	140	181	HD38T004	SE06V108
H-195	228.18	250	244	FALSE	271	140	140	140	181	HD38T004	SE06V108
H-196	227.00	250	267	TRUE	271	140	140	140	180	HD38T004	SE06V108

Minimum	192
Maximum	267

2021 MDD + FF - 70% TWL											
Label	Elevation (m)	Fire Flow (Needed) (L/s)	Fire Flow (Available) (L/s)	Satisfies Fire Flow Constraints?	Hydraulic Grade (m)	Pressure (Residual Lower Limit) (kPa)	Pressure (Zone Lower Limit) (kPa)	Pressure (Calculated Residual) (kPa)	Pressure (Calculated Zone Lower Limit) (kPa)	Junction w/ Minimum Pressure (System)	Junction w/ Minimum Pressure (Zone)
GJ10H006	234.42	250	238	N/A	272	140	140	140	195	HD38T004	SE06V108
GJ10H007	234.73	250	236	N/A	272	140	140	140	195	HD38T004	SE06V108
GJ10H008	233.63	250	243	N/A	272	140	140	140	195	HD38T004	SE06V108
GJ10H009	232.91	250	247	N/A	272	140	140	140	194	HD38T004	SE06V108
GJ10H010	232.43	250	252	N/A	272	140	140	140	194	HD38T004	SE06V108
GJ10H011	232.63	250	222	N/A	272	140	140	140	196	HD38T004	SE06V108
GJ10H012	233.64	250	234	N/A	272	140	140	140	195	HD38T004	SE06V108
GJ10H014	232.48	250	269	N/A	272	140	140	140	193	HD38T004	SE06V108
H-187	232.70	250	242	FALSE	272	140	140	140	195	HD38T004	SE06V108
H-188	234.54	250	215	FALSE	272	140	140	140	196	HD38T004	SE06V108
H-189	234.85	250	205	FALSE	272	140	140	140	196	HD38T004	SE06V108
H-190	232.22	250	214	FALSE	272	140	140	140	196	HD38T004	SE06V108
H-191	234.91	250	200	FALSE	272	140	140	140	197	HD38T004	SE06V108
H-192	229.00	250	235	FALSE	272	140	140	140	195	HD38T004	SE06V108
H-193	229.11	250	238	FALSE	272	140	140	140	195	HD38T004	SE06V108
H-195	228.18	250	252	TRUE	272	140	140	140	194	HD38T004	SE06V108
H-196	227.00	250	276	TRUE	272	140	140	140	193	HD38T004	SE06V108

Minimum	200
Maximum	276



Fire Flow Tables
Full Buildout - Option 2

221-10826-00

2021 MDD + FF - 99% TWL											
Label	Elevation (m)	Fire Flow (Needed) (L/s)	Fire Flow (Available) (L/s)	Satisfies Fire Flow Constraints?	Hydraulic Grade (m)	Pressure (Residual Lower Limit) (kPa)	Pressure (Zone Lower Limit) (kPa)	Pressure (Calculated Residual) (kPa)	Pressure (Calculated Zone Lower Limit) (kPa)	Junction w/ Minimum Pressure (System)	Junction w/ Minimum Pressure (Zone)
GJ10H006	234.42	250	251	N/A	274	140	140	140	213	HD38T004	SE06V108
GJ10H007	234.73	250	249	N/A	274	140	140	140	213	HD38T004	SE06V108
GJ10H008	233.63	250	255	N/A	274	140	140	140	213	HD38T004	SE06V108
GJ10H009	232.91	250	260	N/A	274	140	140	140	212	HD38T004	SE06V108
GJ10H010	232.43	250	264	N/A	274	140	140	140	212	HD38T004	SE06V108
GJ10H011	232.63	250	233	N/A	274	140	140	140	214	HD38T004	SE06V108
GJ10H012	233.64	250	246	N/A	274	140	140	140	213	HD38T004	SE06V108
GJ10H014	232.48	250	283	N/A	274	140	140	140	211	HD38T004	SE06V108
H-187	232.70	250	254	TRUE	274	140	140	140	213	HD38T004	SE06V108
H-188	234.54	250	227	FALSE	274	140	140	140	214	HD38T004	SE06V108
H-189	234.85	250	216	FALSE	274	140	140	140	213	HS-J-1116	SE06V108
H-190	232.22	250	224	FALSE	274	140	140	140	214	HD38T004	SE06V108
H-191	234.91	250	211	FALSE	274	140	140	140	213	HS-J-1115	SE06V108
H-192	229.00	250	245	FALSE	274	140	140	140	209	HS-J-1107	SE06V108
H-193	229.11	250	249	FALSE	274	140	140	140	213	HD38T004	SE06V108
H-195	228.18	250	262	TRUE	274	140	140	140	212	HD38T004	SE06V108
H-196	227.00	250	287	TRUE	274	140	140	140	211	HD38T004	SE06V108

Minimum	211
Maximum	287



Fire Flow Tables
Full Buildout - Option 2

221-10826-00

2031 MDD + FF - 50% TWL											
Label	Elevation (m)	Fire Flow (Needed) (L/s)	Fire Flow (Available) (L/s)	Satisfies Fire Flow Constraints?	Hydraulic Grade (m)	Pressure (Residual Lower Limit) (kPa)	Pressure (Zone Lower Limit) (kPa)	Pressure (Calculated Residual) (kPa)	Pressure (Calculated Zone Lower Limit) (kPa)	Junction w/ Minimum Pressure (System)	Junction w/ Minimum Pressure (Zone)
GJ10H006	234.42	250	218	N/A	269	140	140	140	177	HD38T004	SE06V108
GJ10H007	234.73	250	215	N/A	269	140	140	140	177	HD38T004	SE06V108
GJ10H008	233.63	250	223	N/A	269	140	140	140	177	HD38T004	SE06V108
GJ10H009	232.91	250	227	N/A	269	140	140	140	176	HD38T004	SE06V108
GJ10H010	232.43	250	232	N/A	269	140	140	140	176	HD38T004	SE06V108
GJ10H011	232.63	250	205	N/A	269	140	140	140	178	HD38T004	SE06V108
GJ10H012	233.64	250	215	N/A	269	140	140	140	177	HD38T004	SE06V108
GJ10H014	232.48	250	235	N/A	269	140	140	158	176	HD38T004	SE06V108
H-187	232.70	250	223	FALSE	269	140	140	140	177	HD38T004	SE06V108
H-188	234.54	250	198	FALSE	269	140	140	140	178	HD38T004	SE06V108
H-189	234.85	250	188	FALSE	269	140	140	140	178	HD38T004	SE06V108
H-190	232.22	250	198	FALSE	269	140	140	140	178	HD38T004	SE06V108
H-191	234.91	250	183	FALSE	269	140	140	140	179	HD38T004	SE06V108
H-192	229.00	250	220	FALSE	269	140	140	140	177	HD38T004	SE06V108
H-193	229.11	250	223	FALSE	269	140	140	140	177	HD38T004	SE06V108
H-195	228.18	250	233	FALSE	269	140	140	144	176	HD38T004	SE06V108
H-196	227.00	250	233	FALSE	269	140	140	183	176	HD38T004	SE06V108

Minimum	183
Maximum	235

2031 MDD + FF - 70% TWL											
Label	Elevation (m)	Fire Flow (Needed) (L/s)	Fire Flow (Available) (L/s)	Satisfies Fire Flow Constraints?	Hydraulic Grade (m)	Pressure (Residual Lower Limit) (kPa)	Pressure (Zone Lower Limit) (kPa)	Pressure (Calculated Residual) (kPa)	Pressure (Calculated Zone Lower Limit) (kPa)	Junction w/ Minimum Pressure (System)	Junction w/ Minimum Pressure (Zone)
GJ10H006	234.42	250	228	N/A	271	140	140	140	190	HD38T004	SE06V108
GJ10H007	234.73	250	225	N/A	271	140	140	140	190	HD38T004	SE06V108
GJ10H008	233.63	250	232	N/A	271	140	140	140	190	HD38T004	SE06V108
GJ10H009	232.91	250	237	N/A	271	140	140	140	190	HD38T004	SE06V108
GJ10H010	232.43	250	241	N/A	271	140	140	140	189	HD38T004	SE06V108
GJ10H011	232.63	250	213	N/A	271	140	140	140	191	HD38T004	SE06V108
GJ10H012	233.64	250	224	N/A	271	140	140	140	190	HD38T004	SE06V108
GJ10H014	232.48	250	258	N/A	271	140	140	140	189	HD38T004	SE06V108
H-187	232.70	250	232	FALSE	271	140	140	140	190	HD38T004	SE06V108
H-188	234.54	250	206	FALSE	271	140	140	140	191	HD38T004	SE06V108
H-189	234.85	250	197	FALSE	271	140	140	140	192	HD38T004	SE06V108
H-190	232.22	250	206	FALSE	271	140	140	140	191	HD38T004	SE06V108
H-191	234.91	250	192	FALSE	271	140	140	140	192	HD38T004	SE06V108
H-192	229.00	250	227	FALSE	271	140	140	140	190	HD38T004	SE06V108
H-193	229.11	250	230	FALSE	271	140	140	140	190	HD38T004	SE06V108
H-195	228.18	250	243	FALSE	271	140	140	140	189	HD38T004	SE06V108
H-196	227.00	250	267	TRUE	271	140	140	140	188	HD38T004	SE06V108

Minimum	192
Maximum	267



Fire Flow Tables
Full Buildout - Option 2

221-10826-00

2031 MDD + FF - 99% TWL											
Label	Elevation (m)	Fire Flow (Needed) (L/s)	Fire Flow (Available) (L/s)	Satisfies Fire Flow Constraints?	Hydraulic Grade (m)	Pressure (Residual Lower Limit) (kPa)	Pressure (Zone Lower Limit) (kPa)	Pressure (Calculated Residual) (kPa)	Pressure (Calculated Zone Lower Limit) (kPa)	Junction w/ Minimum Pressure (System)	Junction w/ Minimum Pressure (Zone)
GJ10H006	234.42	250	241	N/A	273	140	140	140	208	HD38T004	SE06V108
GJ10H007	234.73	250	239	N/A	273	140	140	140	208	HD38T004	SE06V108
GJ10H008	233.63	250	245	N/A	273	140	140	140	208	HD38T004	SE06V108
GJ10H009	232.91	250	250	N/A	273	140	140	140	208	HD38T004	SE06V108
GJ10H010	232.43	250	254	N/A	273	140	140	140	207	HD38T004	SE06V108
GJ10H011	232.63	250	224	N/A	273	140	140	140	209	HD38T004	SE06V108
GJ10H012	233.64	250	237	N/A	273	140	140	140	208	HD38T004	SE06V108
GJ10H014	232.48	250	272	N/A	273	140	140	140	206	HD38T004	SE06V108
H-187	232.70	250	245	FALSE	273	140	140	140	208	HD38T004	SE06V108
H-188	234.54	250	218	FALSE	273	140	140	140	209	HD38T004	SE06V108
H-189	234.85	250	208	FALSE	273	140	140	140	208	HS-J-1116	SE06V108
H-190	232.22	250	217	FALSE	273	140	140	140	209	HD38T004	SE06V108
H-191	234.91	250	203	FALSE	273	140	140	140	208	HS-J-1115	SE06V108
H-192	229.00	250	237	FALSE	273	140	140	140	202	HS-J-1107	SE06V108
H-193	229.11	250	241	FALSE	273	140	140	140	206	HS-J-1123	SE06V108
H-195	228.18	250	254	TRUE	273	140	140	140	205	HS-J-1123	SE06V108
H-196	227.00	250	278	TRUE	273	140	140	140	203	HS-J-1123	SE06V108

Minimum	203
Maximum	278




Figure C1 – Simulated AFF under 2021 MDD+FF with 50% TWL (Phase 1)




Figure C2 – Simulated AFF under 2021 MDD+FF with 70% TWL (Phase 1)




Figure C3 – Simulated AFF under 2021 MDD+FF with 99% TWL (Phase 1)




Figure C4 – Simulated AFF under 2031 MDD+FF with 50% TWL (Phase 1)




Figure C5 – Simulated AFF under 2031 MDD+FF with 70% TWL (Phase 1)




Figure C6 – Simulated AFF under 2031 MDD+FF with 99% TWL (Phase 1)




Figure C7 – Simulated AFF under 2021 MDD+FF with 50% TWL (Ultimate Buildout)




Figure C8 – Simulated AFF under 2021 MDD+FF with 70% TWL (Ultimate Buildout)




Figure C9 – Simulated AFF under 2021 MDD+FF with 99% TWL (Ultimate Buildout)




Figure C10 – Simulated AFF under 2031 MDD+FF with 50% TWL (Ultimate Buildout)




Figure C11 – Simulated AFF under 2031 MDD+FF with 70% TWL (Ultimate Buildout)




Figure C12 – Simulated AFF under 2031 MDD+FF with 99% TWL (Ultimate Buildout)




Figure C13 – Simulated AFF under 2021 MDD+FF with 50% TWL (Ultimate Buildout – Option 2)




Figure C14 – Simulated AFF under 2021 MDD+FF with 70% TWL (Ultimate Buildout – Option 2)




Figure C15 – Simulated AFF under 2021 MDD+FF with 99% TWL (Ultimate Buildout – Option 2)




Figure C16 – Simulated AFF under 2031 MDD+FF with 50% TWL (Ultimate Buildout – Option 2)




Figure C17 – Simulated AFF under 2031 MDD+FF with 70% TWL (Ultimate Buildout – Option 2)




Figure C18 – Simulated AFF under 2031 MDD+FF with 99% TWL (Ultimate Buildout – Option 2)

APPENDIX

D

FLUSHING REPORT



Flushing Reports
Phase 1

221-10826-00

Label	Length (m)	Diameter (mm)	Flushing Event	Velocity (Maximum Flushing) (m/s)	Satisfies Flushing Target Velocity?	Flow (Absolute) (L/s)	No. of Port
HS-P-893	30.18	300.00	Event [HS-J-1123]	0.92	TRUE	1.29	1
HS-P-887	28.96	300.00	Event [HS-J-1123]	0.92	TRUE	1.29	1
HS-P-889	53.34	300.00	Event [HS-J-1123]	0.92	TRUE	1.29	1
HS-P-888	130.15	300.00	Event [HS-J-1123]	0.92	TRUE	1.29	1
HS-P-890	179.22	300.00	Event [H-189]	0.92	TRUE	1.29	1
HS-P-892	54.86	300.00	Event [H-188]	0.93	TRUE	1.29	1
HS-P-891	128.32	300.00	Event [H-188]	0.93	TRUE	1.29	1
HS-P-883	84.12	300.00	Event [H-187]	0.96	TRUE	1.29	1

Minimum	0.92
Maximum	0.96



Flushing Reports

221-10826-00

Label	Length (m)	Diameter (mm)	Flushing Event	Velocity (Maximum Flushing) (m/s)	Satisfies Flushing Target Velocity?	Flow (Absolute) (L/s)	No. of Port
P-887	28.96	300.00	Event [J-1135]	0.88	TRUE	3.83	2
P-888	130.15	300.00	Event [J-1135]	0.88	TRUE	3.83	2
P-889	53.34	300.00	Event [J-1135]	0.88	TRUE	3.83	2
P-886	80.47	300.00	Event [J-1135]	0.90	TRUE	2.44	2
P-877	20.12	300.00	Event [J-1135]	0.95	TRUE	0.50	2
P-878	151.79	300.00	Event [J-1135]	0.95	TRUE	0.50	2
P-890	179.22	300.00	Event [H-188]	1.01	TRUE	3.83	2
P-872	23.77	300.00	Event [J-1104]	1.17	TRUE	0.50	2
P-891	128.32	300.00	Event [H-184]	1.18	TRUE	3.83	2
P-892	54.86	300.00	Event [H-184]	1.18	TRUE	3.83	2
P-870	72.54	300.00	Event [J-1104]	1.19	TRUE	1.57	2
P-871	224.64	300.00	Event [J-1104]	1.19	TRUE	1.57	2
P-883	84.12	300.00	Event [H-185]	1.45	TRUE	3.83	2
P-873	11.28	300.00	Event [J-1104]	1.83	TRUE	0.00	2
P-874	88.09	300.00	Event [J-1104]	1.83	TRUE	0.00	2
P-875	178.92	300.00	Event [J-1104]	1.83	TRUE	0.00	2
P-876	78.33	300.00	Event [J-1104]	1.83	TRUE	0.00	2

Minimum	0.88
Maximum	1.83



Flushing Reports
Full Buildout - Option 2

221-10826-00

Label	Length (m)	Diameter (mm)	Flushing Event	Velocity (Maximum Flushing) (m/s)	Satisfies Flushing Target Velocity?	Flow (Absolute) (L/s)	No. of Port
HS-P-878	63.7	300	Event [H-191]	0.97	TRUE	5.17	2
HS-P-877	109.42	300	Event [H-191]	0.98	TRUE	6.17	2
HS-P-876	78.33	300	Event [H-191]	0.98	TRUE	6.17	2
HS-P-886	80.47	300	Event [H-190]	0.93	TRUE	2.45	2
HS-P-887	28.96	300	Event [H-190]	0.81	TRUE	1.16	2
HS-P-889	53.34	300	Event [H-191]	0.96	TRUE	1.16	2
HS-P-888	130.15	300	Event [H-191]	0.96	TRUE	1.16	2
HS-P-875	178.92	300	Event [H-190]	0.99	TRUE	6.17	2
HS-P-890	179.22	300	Event [H-189]	1.06	TRUE	1.16	2
HS-P-874	88.09	300	Event [H-192]	1.14	TRUE	6.17	2
HS-P-892	54.86	300	Event [H-188]	1.18	TRUE	1.16	2
HS-P-891	128.32	300	Event [H-188]	1.18	TRUE	1.16	2
P-886(1)	124.66	300	Event [H-193]	1.2	TRUE	6.17	2
P-886(2)(1)	170.99	300	Event [H-195]	1.32	TRUE	6.17	2
HS-P-883	84.12	300	Event [H-187]	1.38	TRUE	1.16	2
P-886(2)(2)	87.48	300	Event [H-196]	1.54	TRUE	6.17	2

Minimum	0.81
Maximum	1.54




Figure D1 – Flushing Results for the Proposed 3054 Homestead Drive Development (Phase 1)




Figure D2 – Flushing Results for the Proposed 3054 Homestead Drive Development (Ultimate Buildout)





Figure D3 – Flushing Results for the Proposed 3054 Homestead Drive Development (Ultimate Buildout – Option 2)

APPENDIX

E

HYDRANT FLOW TEST RESULTS

9079 Airport Rd (GJ10H011)



Subject Watermain Details

Diameter: 400 mm Material: DI
Area: 0.126 m²

Subject Hydrant & Valve Details

Residual Hydrant: GJ10H011
Flow Hydrant 1: GJ10H012
Flow Hydrant 2: GJ10H010

TABLE A: TESTED PRESSURES AND FLOWS

Point	Time		Residual (GJ10H011)		Flow Hydrant 1 (GJ10H012)				Flow Hydrant 2 (GJ10H010)				Total Flow		Velocity
			Residual (S1)		Flow 1 (S2)		Flow 2 (S3)		Flow 3 (S4)		Flow 4 (S5)				
	Start	Finish	(kPa)	(psi)	(L/s)	(GPM)	(L/s)	(GPM)	(L/s)	(GPM)	(L/s)	(GPM)	(L/s)	(GPM)	(m/s)
Static	52	159	376	54.5	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
1 x 2"			0	0.0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2 x 2"	423	487	355	51.5	36.3	575	22.6	358	0.0	0	0.0	0	58.9	934	0.5
3 x 2"	599	674	330	47.9	35.6	564	23.3	369	64.2	1018	0.0	0	123.1	1951	1.0
4 x 2"	765	811	309	44.8	34.5	547	22.5	357	55.4	878	51.9	823	164.3	2604	1.3



9079 Airport Rd (GJ10H011)

HYDRANT FLOW TEST RESULTS

Date: 13-Oct-22

Time: 9:41
(hh/mm)


Municipality: City of Hamilton

Operator:

Tested By: Sen, Issac

Test No:

1



Conditions before Test (STATIC)

Residual Hydrant: 54.5 psi 376 kPa

Hydrant that will Flow: 54.5 psi 376 kPa

Δ pressure: 0.0 psi 0 kPa


Elevation Difference: 0.0 ft 0.0 m

(Flow El. - Residual El.)

Test Notes:

TEST		TEST FLOW		RESIDUAL PRESSURE (psi)		Minimum Residual P, (psi)	Fire Flow at Minimum Residual, Q, (USGPM)	Fire Flow at Minimum Residual, Q, (L/s)	10% Pressure Drop Achieved?
Port Size (in)	Nozzle Pressure (psi)	(USGPM)	(L/s)	Monitoring Hydrant	Flow Hydrant (Corrected) *				
STATIC	n/a	0	0	54.5	54.5				
Single Hydrant Test									
1 x 2"	0.0	0.0	0.0			20			
2 x 2"	8.9	933.0	58.9	51.5	51.5	20	3469	219	NO
3 x 2"									
Hydrant 1	8.9	933.0	58.9	47.9	47.9	20	4755	300	YES
Hydrant 2	37.0	1018.0	64.2						
4 x 2"									
Hydrant 1	8.4	904.0	57.0	44.8	44.8	20	5162	326	YES
Hydrant 2	25.8	1701.0	107.3						

* Pressure correction is equal to the elevation difference. Column 2 (and Table A) show the nozzle pressure while flowing.



Results			
Static Pressure		Flow at 20 psi (140kPa)*	
(psi)	(kPa)	(gpm)	(L/s)
54.5	376	5200	328

* Results carried to nearest 50 gpm or 100 gpm if over 1000 gpm

Hydrant Classification as per NFPA 291			
Class	AA	Color	BLUE

Water Discharged During Test:	43500 L
-------------------------------	---------

Rounded up to closest 100L


DISCLAIMER FOR FIRE FLOW TESTS

While WSP makes every effort to ensure that the information contained herein is accurate and up to date, WSP is not responsible for unintended or incorrect use of the data and information described and/or contained herein. The user must make his/her own determination as to its accuracy and suitability. The information is representative for a dynamic water system that may change over time.

© WSP Canada Inc. 2022.

This information sheet can be reproduced by the client for internal use but not redistributed to third parties without the written authorization of WSP.

3026 Homestead Dr (GJ10H006)



Subject Watermain Details			Subject Hydrant & Valve Details		
Diameter:	400 mm	Material:	DI	Residual Hydrant:	GJ10H006
Area:	0.126 m2			Flow Hydrant 1:	GJ10H008
				Flow Hydrant 2:	GJ10H007

TABLE A: TESTED PRESSURES AND FLOWS

Point	Time		Residual (GJ10H006)		Flow Hydrant 1 (GJ10H008)				Flow Hydrant 2 (GJ10H007)				Total Flow		Velocity
			Residual (S1)		Flow 1 (S2)		Flow 2 (S3)		Flow 3 (S4)		Flow 4 (S5)				
	Start	Finish	(kPa)	(psi)	(L/s)	(GPM)	(L/s)	(GPM)	(L/s)	(GPM)	(L/s)	(GPM)	(L/s)	(GPM)	(m/s)
Static	110	280	375	54.4	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
1 x 2"			0	0.0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2 x 2"	450	540	377	54.7	37.7	598	34.0	539	0.0	0	0.0	0	71.7	1136	0.6
3 x 2"	632	708	353	51.2	38.0	602	34.7	550	64.0	1014	0.0	0	136.7	2167	1.1
4 x 2"	807	842	332	48.2	36.5	579	31.3	496	45.4	720	44.6	707	157.8	2501	1.3



3026 Homestead Dr (GJ10H006)

HYDRANT FLOW TEST RESULTS

Date: 19-Oct-22

Time: 9:36
(hh/mm)


Municipality: City of Hamilton

Operator:

Tested By: Sen, Issac

Test No:

2



Conditions before Test (STATIC)

Residual Hydrant: 54.4 psi 375 kPa

Hydrant that will Flow: 54.4 psi 375 kPa

Δ pressure: 0.0 psi 0 kPa


Elevation Difference: 0.0 ft 0.0 m

(Flow El. - Residual El.)

Test Notes: A pump may have started during test

TEST		TEST FLOW		RESIDUAL PRESSURE (psi)		Minimum Residual P _r (psi)	Fire Flow at Minimum Residual, Q _r (USGPM)	Fire Flow at Minimum Residual, Q _r (L/s)	10% Pressure Drop Achieved?
Port Size (in)	Nozzle Pressure (psi)	(USGPM)	(L/s)	Monitoring Hydrant	Flow Hydrant (Corrected) *				
STATIC	n/a	0	0	54.4	54.4				
Single Hydrant Test									
1 x 2"	0.0	0.0	0.0			20			
2 x 2"	13.3	1137.0	71.7	54.7	54.7	20	N.A.	N.A.	NO
3 x 2"									
Hydrant 1	13.6	1152.0	72.7	51.2	51.2	20	7822	494	NO
Hydrant 2	36.7	1014.0	64.0						
4 x 2"									
Hydrant 1	11.9	1075.0	67.8	48.2	48.2	20	6316	399	YES
Hydrant 2	18.2	1427.0	90.0						

* Pressure correction is equal to the elevation difference. Column 2 (and Table A) show the nozzle pressure while flowing.



Results			
Static Pressure		Flow at 20 psi (140kPa)*	
(psi)	(kPa)	(gpm)	(L/s)
54.4	375	6300	397

* Results carried to nearest 50 gpm or 100 gpm if over 1000 gpm

Hydrant Classification as per NFPA 291			
Class	AA	Color	BLUE

Water Discharged During Test:	39300 L
-------------------------------	---------

Rounded up to closest 100L

DISCLAIMER FOR FIRE FLOW TESTS

While WSP makes every effort to ensure that the information contained herein is accurate and up to date, WSP is not responsible for unintended or incorrect use of the data and information described and/or contained herein. The user must make his/her own determination as to its accuracy and suitability. The information is representative for a dynamic water system that may change over time.

© WSP Canada Inc. 2022.

This information sheet can be reproduced by the client for internal use but not redistributed to third parties without the written authorization of WSP.

Table E1: Hydrant Flow Test vs. Simulated Flow Test Results @ Hydrant GJ10H011

GJ10H011				
Source	Static Pressure (kPa)	Residual Pressure (kPa)	Test Flow (L/s)	Theoretical Flow Available at 20 psi Residual (L/s)
Hydrant Test	376	309	164	328
Model Curve	364	243	164	240




Figure E1: Hydrant Flow Test vs. Simulated Flow Test Results @ Hydrant GJ10H011

Table E2: Hydrant Flow Test vs. Simulated Flow Test Results @ Hydrant GJ10H006

GJ10H006				
Source	Static Pressure (kPa)	Residual Pressure (kPa)	Test Flow (L/s)	Theoretical Flow Available at 20 psi Residual (L/s)
Hydrant Test	377	332	158	398
Model Curve	373	260	158	246




Figure E2: Hydrant Flow Test vs. Simulated Flow Test Results @ Hydrant GJ10H006